



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the genl

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.



0124-2322427



0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

M/s Signature Builder Pvt. Ltd.
1309, 13th Floor, Dr. Gopal Dass Bhawan
28, Barakhamba Road, Connaught Place
New Delhi-110001.
Email:compliance@signatureglobal.in

Memo No. Ch.09 / Drg.-PLC

Dated: 19 / 01 / 2023

Sub: Power assurance our proposed Affordable Residential Plotted colony under (DDJAY) scheme (17.31875 Acres) falling in the revenue estate of village-Wazirpur, Sec-93, Distt-Gurugram. Declared Load 2011 KVA.

Ref: Your firm letter dated 05.01.2023.

Reference your request, the technical feasibility has been checked by Sh. K.C.Sharma -J.E. and based on his recommendation given at noting page No.2 of file Drg./PLC on dated 14.01.2022, it is conveyed that power requirement of your project bearing License No. 210 of 2022 dated 22.12.2022 shall be considered from the nearest 220/33KV S/Stn., Gurugram at the time of release of load. The voltage level of supply will be at 33KV level irrespective of load as DHBVN has been adopted 33KV level of distribution in Sec-58-115 and Sec-37C and 37D of Gurugram. The load requirement of this project would be evaluated as per DHBVN norms, However, this assurance is subject to the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per instructions of the Nigam and compliance of all other instructions of Nigam will be ensured as per standing instructions of the Nigam/HERC regulation.
3. The necessary 33/0.433 KV external & internal infrastructure will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer for getting environment clearance from Pollution Control Board of Haryana.
5. As per Nigam's instruction the validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applied for revised assurance letter.


Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' Divn. DHBVN Manesar.