



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the Genl



0124-2322427

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.



0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

✓ M/s Metro Education & Welfare Pvt. Ltd.
Office No. 12A Floor, Tower-2, M3M International Financial Center,
Sec-66, Gurugram (HR) -122002
e-mail-metroeducation1204@gmail.com;

Memo No. Ch-99 / Drg.-PLC

Dated: 31 /12/2022

Sub:

Request to issue Power Assurance letter for Proposed Group Housing Colony under TOD Zone (Mix Land Use) to be developed on Land measuring in 15.99375 Acre under License No. 213 of 2022 in revenue estate of Village-Chauma, Sec-111, Gurugram, Haryana by M/s Metro Education & Welfare Pvt. Ltd. Decalared load 16731 KW / 18589 KVA.

Ref :

Your Firm Letter No. M3M/2022/12/29 Dated 29.12.2022 recived vide Email dated 29.12.2022 at 12:22 PM.

With reference to your request, the technical feasibility has been checked by Sh. K.C. Sharma JE-I of this office and recommendation given at Noting Page No.17 of file Drg/PLC dated 31.12.2022, it is conveyed that power requirement of your project bearing License No. 213 Of 2022 Dated 27.12.2022 which is Valid upto 26.12.2027 shall be considered from the nearest source i.e. 220 KV S/Stn., Sec-110, Gurugram or any other source at the time of release of your load at 33 KV level or the level applied at the time of release of load . The load requirement of this project would be evaluated as per DHBVN norms. The assurance is subject the following conditions:-

1. Availability of power and infrastructure at the time of actual release of load.
2. Deposition of necessary charges by you as per instructions of the Nigam and compliance of all other instructions of Nigam as per standing instructions of the Nigam/HERC regulation.
3. The necessary external & internal infrastructure as per approved Electrification Plan will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance Letter has been issued for subject sited consumer to get environment clearance from Pollution Control Board of Haryana.
5. The validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applying for revised assurance letter.


Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' City Divn. DHBVN for information.