



# DAKSHIN HARYANA BIJLI VITRAN NIGAM

( A Government of Haryana Undertaking)  
Office of the gmol

Superintending Engineer 'OP' Circle-I  
Mehrauli Road, Gurugram.



0124-2322427



0124-2306590

e-mail [seop1gurugram@dhbvn.org.in](mailto:seop1gurugram@dhbvn.org.in)



To

M/s Airmid Developers Ltd,  
Albina Properties Ltd,  
448-451, Udyog Vihar Phase-V,  
Gurugram , Haryana

(Registered)

Memo No. Ch.08 / Drg.-PLC

Dated: 21/09/2022

Sub:

Assurance Certificate/NOC for supply of electrical load w.r.t Commercial Colony land measuring 6.525 Acres (License No. 79 of 2012 dated 17.08.2012 and License No. 11 of 2013 dated 12.03.2013) being developed by Airmid Developers Limited, Sector106, Gurugram Declared Load-8240KW.

Ref:

- 1.The firm letter dated 11.07.2022 on the subject.
- 2.This office Memo No. Ch-59/Drg/PLC dated 19.07.2022.
- 3.The firm letter dated 26.07.2022 received in this office on dated 01.08.2022.
- 4.This office Memo No. Ch-77/Drg/PLC dated 05.08.2022.
5. The Xen 'OP' City divn DHBVN Gurugram Memo No. 194/Drg/UL dated 16.9.2022.

Reference your request, the technical feasibility has been checked by Xen 'OP' and based on his recommendation it is conveyed that power requirement of your project bearing license No. 79 of 2012 dated 17.08.2012 which is valid upto 16.08.2024 & license No. 11 of 2013 dated 12.03.2013 which is valid upto 11.03.2024 shall be considered from the nearest 220/33KV S/Stn., Gurugram at the time of release of load. The voltage level of supply will be 33KV irrespective of load as DHBVN has been adopted 33KV level of distribution in Sec-58 to 115 & Sec-37C and Sec-37D of Gurugram. The load requirement of this project would be evaluated as per DHBVN norms, However, this assurance is subject to the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary 33/0.433KV external & internal infrastructure will be laid by you at your own cost as per sanctioned load /EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer to get environment clearance from Pollution Control Board of Haryana.
5. As per Nigam's instruction the validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applied for revised assurance letter.

Superintending Engineer  
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' City Divn. Gurugram w.r.t his office Memo No. 194/Drg/UL dt 16.9.2022 for information.