

1. BUILDING HAS AUTOMATIC SPRINKLER SYSTEM WHEREVER REQUIRED BY NBC.

2. BUILDING WILL BE DESIGNED (STRUCTURES) AS PER RELEVANT IS CODES FOR EARTH QUAKE RESISTANCE.

AS PER RELEVANT IS CODES FOR EARTHQUAKE RESISTANCE.

ATP(HQ)

Service and routing OK for Public Health
(Internal) Service only subject to comments in
in forwarding letter No. 347. D.V. 08/01/92

Superintending Engineer (HQ,
for Chief Engineer IASVP
Panchkula
SgE (ur)

PROPOSED COMMERCIAL COLONY AREA
MEASURING 6,525 ACRES (LICENSE NO. 79 OF 2012)
DATED 17/08/2012 & LICENSE NO. 11 OF 2013 DATED
12/03/2013 IN SECTOR 106, GURGRAM BEING
DEVELOPED BY ETLAN AVENUE LTD.(FORMELY
KNOWN AS AIRMID DEVELOPERS LTD.)

ARCHITECT

OWNER'S SEAL
& SIGNATUREARCHITECT'S SEAL
& SIGNATURE

AMINASH CHANDRA VIDYA
Architect No. CA751023035
H. No. 163, PH-1
New Palm Vihar, Gurgaon

DEC.-2022.	Scale : 1:150	
Drawing Title:-		Drawing No

6TH FLOOR

T-08

Door Type	Applc	Dimensions				Performance			
		Rating	Width	Mass/Height	Cell Height	Material	Insulation	Sound	
D1		NA	1200	2400		2400	2400	2400	
D2	Flth	NA	800	2300	100	2400	2400	2400	
D3	Door	NA	1000	2400		2400	2400	2400	
D4	Fl	NA	2150	2400		2400	2400	2400	
F1		2	2150	2400		2400	2400	2400	
F1a		2	2150	2400		2400	2400	2400	
F1b		2	2150	2400		2400	2400	2400	
F2		2	2000	2400		2400	2400	2400	
F2a	Meal	2	2000	2400		2400	2400	2400	
F3	door	2	1200	2400		2400	2400	2400	
F3a		2	1200	2400		2400	2400	2400	
F4		2	1200	2400		2400	2400	2400	
F4a		2	800	2000	100	2400	2400	2400	
F5		2	1500	2200	100	2400	2400	2400	
G1	GLSS	NA	1200	2400		2400	2400	2400	
G2	door	2	2000	2400		2400	2400	2400	

[illegible]

REQUIRED STAIRCASE WIDTH 6TH TO 11TH FLOOR CALCULATION:-
Office area (2820 sqm @ 1 person / 10 sqm) = 282 persons
Required staircase width for Retail @ 10mm/person for 282 persons = 2820 mm i.e. MINIMUM 3000MM.
Proposed staircase width for Retail = 6000MM.