

From

Director,  
Urban Local Bodies, Haryana,  
S.C.O.No. 6-7, Sector 17B,  
Chandigarh.

To

✓ M/S S.L.F. Anushree Apartment,  
Sector 75-76, Faridabad.

Memo No. FA/2008/  
Dated

26018  
24/6/08

Subject :-

Approval of Fire Fighting scheme from Fire Safety Point of view for the proposed Group Housing Scheme, Sector 75-76, Faridabad.

Reference on the subject cited above.

2. The case for the approval for the fire Fighting Scheme has been examined by the Asstt.Divisional Fire Officer, Municipal Corporation, Faridabad. The Fire Fighting Scheme has been found as per the National Building Code of India, Part IV, 1983 revised 2005, so the proposed fire fighting scheme is approved from fire safety point of view only with the following conditions:-

1. The proposed Fire Fighting scheme is approved in the building plan submitted, subject to the approval of Building plan as per rules applicable;
2. The overhead water tank for fire fighting shall be constructed in such a way that domestic water tank shall be filled from overflow of Fire water tank.
3. As soon as the installation of fire fighting arrangements are completed, the same may be got inspected/tested and clearance should be obtained from this department.

  
Fire Officer, HQ  
For Director, Urban Local Bodies, Haryana,  
Chandigarh.

Endst.No. FA/2008/

Dated

A copy is forwarded to the Commissioner, Municipal Corporation, Faridabad w.r.t his Memo No. 298, dated 23.06.2008 for information and necessary action.

Fire Officer, HQ  
For Director, Urban Local Bodies, Haryana,  
Chandigarh..

PHOTO COPY ATTESTED

Notary Faridabad (Haryana)



29 JUL 2008

Director,  
Fire Service, Haryana,  
Panchkula.

To

M/s SLF Anushree Apartments village-Martjapur,  
Sec-75-76, Faridabad.

Memo No. DFS/F.A./2017/589/  
Dated:

9459/09/217

**Subject: Approval of fire fighting scheme from the fire safety point of view of the Residential Building of Site -II (Tower P1,P2,P1,P3, Nursery School & EWS Block & Basement) meas. 10.925 acres at Vill- Martjapur, Sector-75-76, Faridabad of M/s SLF Anushree Apartments.**

Reference on the subject cited above.

Your case for the approval of fire fighting scheme has been examined as recommended by the Asst. Divisional Fire Station Officer, Faridabad. The Fire fighting scheme is found as per the N.B.C. 1983 Part IV revised 2005/ guidelines. Therefore, your proposed fire fighting scheme is hereby approved from the fire safety point of view with the following conditions:-

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un-noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building.

*Deep*  
8/2/17

Fire Officer (HQ)  
for Director, Haryana Fire Service,  
Panchkula.

Endst. No- DFS/F.A./2017/589/

Dated

A copy is forwarded to the Asst. Divisional Fire Station Officer, Faridabad with reference to his Memo No. ADFO/2016/G/426, dated 08.08.2016 for information and necessary action.

PHOTO COPY ATTESTED



*sd*  
Fire Officer (HQ)  
for Director, Haryana Fire Service,  
Panchkula.