



# DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)  
Office of the general

Superintending Engineer 'OP' Circle-I  
Mehrauli Road, Gurugram.



0124-2322427

Fax  
No.

0124-2306590

e-mail [seop1gurugram@dhbvn.org.in](mailto:seop1gurugram@dhbvn.org.in)



To

M/s Diverse Developers LLP.  
M-18, Market-m-Block, Greater Kailash-II  
New Delhi-110048. (E-mail: cs@rof.co.in)

Memo No. Ch. 93/ Drg.-PLC

Dated: 13/09/2021

Sub:

Assurance of power supply load & ultimate power load 2763.4 KVA for Affordable Plotted Colony under DDJAY over an area measuring 9.3694 acres project in the revenue estate of village - Badha & Hayatpur, Sector-93, Gurugram by M/s Diverse Developers LLP.

Reference your firm letter dated 06.08.2021 received in this office on 18.08.2021.

It is hereby assured that the power requirement of electrical load of 2763.4 KVA shall be considered from the nearest 220/33KV S/Stn. at the time of actual requirement as per DHBVN Norms and the voltage level of supply will be at 33KV subject to the following conditions: -

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary external and internal infrastructure will be laid by you at your own cost.
4. The assurance letter has been issued to subject cited consumer for environment clearance from Pollution Control Board of Haryana .
5. The validity of this letter will be for a period of maximum one year from the date of its issuance as per sales instruction No. 7/2018 circulated vide SE/Comml, DHBVN, Hisar Memo No. Ch-7/SE/Comml/R-17/380/F-21 dated 16/08/2018.

Superintending Engineer  
'OP' Circle-I DHBVN, Gurugram

Copy to : -

The XEN 'OP Divn. DHBVN, Manesar w.r.t.his office Memo No.1487 dated 01.09.2021.