

P/S/13/17

**DAKSHIN HARYANA BIJLI VITRAN NIGAM**  
(A Power Distribution & Retail Supply Utility, Govt. of Haryana)  
An ISO 9001: 2008 Compliant Utility, CIN: U99999HR-1999SG034165  
Chief Engineer/Commercial, DHBVN, Hisar,  
Regd. Office: Vidyut Sadan, Vidyut Nagar, Hisar-125005 (Haryana)  
Phone No. 01662-223093, Fax No. 01662223153  
Website: [dhbvn.org.in](http://dhbvn.org.in) E-Mail: [cecommercialdhbvn@gmail.com](mailto:cecommercialdhbvn@gmail.com)

---

To

SE/OP Circle,  
DHBVN, Gurugram-I.

**Memo No. Ch-5/SE/C-SOL-157**

**Dated: 26/10/2017**

**Subject:- Approval of revised load 4618KW or 5131KVA with Electrification Plan against already sanctioned load of 6659KW (7399KVA) to M/s Oasis Buildhome Pvt. Ltd., Sector-89A, Vill-Harsaru, Gurugram under SDO OP S/Divn., DHBVN, Farukh Nagar.**

Please refer to the request of applicant for revision of Load dated 28/7/2017 on above subject:-

Approval for revision of load 4618KW or 5131KVA against already sanctioned load 6659KW (7399KVA) along with electrification plan on single point connection to M/s Oasis Buildhome Pvt. Ltd., Sector-89A, Vill-Harsaru, Gurugram under HT/BS/DS category, is hereby accorded, subject to compliance of the terms and conditions given as under:-

1. The revised load of 4618KW or 5131KVA shall be fed from proposed 220/33 KV S/Stn., Sector-95, Gurugram through proposed 33KV independent feeder with double run 3Cx300mm<sup>2</sup> XLPE U/G Cable at the cost of applicant.
2. The developer shall install 2 nos. T/F 1250KVA, and 01 no. 1000KVA, 33/11/0.4KV, Oil Type Transformers & 2 no. 1600KVA, 33/11/0.4KV, Dry Type Transformers (Total capacity 6700KVA) to cater their ultimate load by considering maximum loading of 80% of the rating of each T/F. Since the developer has proposed to install T/Fs, so, from safety aspect an NOC in this regard may be obtained from Chief Electrical Inspector, besides ensuring compliance of all safety measures by SE/Op, Gurugram-I.
3. The applicant shall comply with the provision of Haryana Renewable Energy Department regarding installation of solar photovoltaic Power Plant applicable from time to time.
4. All the other terms and conditions mentioned in the ibid memo no. Ch-03/SE/C-SOL-157 dated 12.11.2016 shall remain unchanged.

This issues with the approval of Director/Project, DHBVN, Hisar at NP-07 of file no. SOL-157.

*Jul*  
CE/Commercial,  
DHBVN, Hisar

CC to:-

1. The SPS to Director/Project, DHBVN, Hisar for kind information of Director/Project, please.
2. The CE/OP, DHBVN, Delhi for kind information, please.
3. The CE/TS, HVPN, Hisar for kind information, please.
4. CE/Planning, HVPN, Panchkula.
5. SE/TS, HVPN, Gurugram.
6. SE/NCR, HVPN, Gurugram.
7. XEN/OP Division, DHBVN, Manesar.
8. SDO/OP S/Divn., DHBVN, Farukh Nagar.
9. M/s Oasis Buildhome Pvt. Ltd., Sector-89A, Vill-Harsaru, Gurugram.