



# DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)  
(Office of the govt)



0124-2322427



0124-2306590



Superintending Engineer 'OP' Circle-I  
Mehrauli Road, Gurugram.

e-mail [seop1gurugram@dhbvn.org.in](mailto:seop1gurugram@dhbvn.org.in)

To

M/s GCC Infra  
P-903-905, C-Wing, 9<sup>th</sup> floor JMD Megapolis  
Sector-48, Sohna Road Gurugram (HR).  
Email: [info@breezbuilders.com](mailto:info@breezbuilders.com)

Memo No. Ch.-12/ Drg.-PLC

Dated:-19/01/2023

**Sub:** Request for Assurance of power supply of 1199.57kW or 1333KVA for our Affordable Residential Plotted Colony DDGAY-2016 area measuring 3.25 acres (License No.5 of 2023) in addition to 7.35 Acres (License No.126 of 2022) in total area measuring 10.625 acres being developed by GCC Infra at Sector-88A Gurugram. Declared Load 1199.57 kW or 1333 KVA.

**Ref:** Your firm letter dated 10.01.2023.

Reference your request, the technical feasibility has been checked by Sh. K.C.Sharma -J.E. and based on his recommendation given at noting page No.2 of file Drg./PLC on dated 14.01.2022, it is conveyed that power requirement of your project bearing License No. 5 of 2023 & 126 of 2022 dated 17.08.2022 which is valid upto 16.08.2027 shall be considered from the nearest 220/33KV S/Stn. Sec-85 Gurugram at the time of release of load. The voltage level of supply will be at 33KV level irrespective of load as DHBVN has been adopted 33KV level of distribution in Sec-58-115 and Sec-37C and 37D of Gurugram. The load requirement of this project would be evaluated as per DHBVN norms, However, this assurance is subject to the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per instructions of the Nigam and compliance of all other instructions of Nigam will be ensured as per standing instructions of the Nigam/HERC regulation.
3. The necessary 33/0.433 KV external & internal infrastructure will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer for getting environment clearance from Pollution Control Board of Haryana.
5. As per Nigam's instruction the validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applied for revised assurance letter.

  
Superintending Engineer  
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' Divn. DHBVN Manesar.