



# DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)  
Office of the group

Superintending Engineer 'OP' Circle-I  
Mehrauli Road, Gurugram.



0124-2322427



0124-2306590

e-mail [seop1gurugram@dhbvn.org.in](mailto:seop1gurugram@dhbvn.org.in)



To

M/s Cordial Infrastructure Pvt. Ltd.  
11th Floor, Paras Twin Towers,  
Sector-54, Gurugram  
E-mail: [generalinfo@parasbuildtech.com](mailto:generalinfo@parasbuildtech.com)

Memo No. Ch.97 / Drg.-PLC

Dated: 28/12/2022

**Sub:** Assurance of Electrical supply for the commercial project named- Paras Arcade 114, at Sector 114, Gurugram being developed by Cordial Infrastructure Pvt. Ltd. (Corporate office at 11th Floor, Paras Twin Towers, Sector-54, Gurugram) vide license No. 45 of 2010 dated 14.06.2010. Declared Load 1.8 MVA

With reference to your request, the technical feasibility has been checked by Sh. K.C. Sharma JE-I of this office and recommendation given at Noting Page No.16 of file Drg/PLC dated 28.12.2022, it is conveyed that power requirement of your project Licence No. 45 of 2010 dated 14.06.2010 which is renewed upto 14.06.2025 shall be considered from the nearest Source i.e. 220 KV S/Stn., Sec-110 or any other source at the time of release of your load at 33 KV level or the level applied at the time of release of load. The load requirement of this project would be evaluated as per DHBVN norms. The assurance is subject the following conditions:-

1. Availability of power and infrastructure at the time of actual release of load.
2. Deposition of necessary charges by you as per instructions of the Nigam and compliance of all other instructions of Nigam as per standing instructions of the Nigam/HERC regulation.
3. The necessary external & internal infrastructure as per approved Electrification Plan will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applying for revised assurance letter.

  
Superintending Engineer  
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' City Divn. DHBVN Gurugram for information.