

DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the Genl

0124-2322427

0124-2306590

e-mail seop1gurugram@dhbvn.org.in



DHBVN

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.

To

M/s MRG World LLP, Pvt. Ltd.
Unit No -110, First Floor, Best Sky Tower,
Netaji Subhash Place, Pitampura, Delhi-110034
Email. compliances@mrgworld.com

Memo No. Ch.26 / Drg.-PLC

Dated:- 16 /12/2021

Sub: Power Assurance for our proposed "Affordable Group Housing Colony" project area measuring 5.2625 acres location at village- Badha, Sec-90, Gurugram, Haryana by M/s MRG World L.L.P.

Ref: Your firm letter No. Nil dated 26.11.2021 on the subject.

It is hereby assured that the power requirement of electrical load of 3655.21KVA shall be considered from the nearest 220/33KV S/Stn., Sec-85, Gurugram as recommended by Xen 'OP' Divn, Manesar Memo No. 3000 dated 13.12.2021 at the time of actual requirement as per DHBVN Norms and voltage level of supply will be at 33KV subject to the following conditions: -

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary external & internal infrastructure will be laid by you at your own cost.
4. The assurance letter has been issued for subject cited consumer to get environment clearance from Pollution Control Board of Haryana.
5. The validity of this letter will be for a period of maximum one year from the date of its issuance as per sales instruction No. 7/2018 circulated vide SE/Comml, DHBVN, Hisar Memo No. Ch-7/SE/Comml/R-17/380/F-21 dated 16/08/2018.

Copy to:-

Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

1. The Xen 'OP' Divn DHBVN Manesar w.r.t his office Memo No. 3000 dated 13.12.2021.