

WATER IS PRECIOUS

**14.209 ACRES, SECTOR 95, GURUGRAM,
HARYANA**

*ESTIMATE FOR PROVIDING WATER SUPPLY, SEWERAGE, STORM WATER DRAINAGE, ROADS, STREET
LIGHTING AND HORTICULTURE IN RESPECT OF 14.209 ACRES AFFORDABLE REDIENTIAL PLOTTED
COLONY IN SECTOR – 95, GURUGRAM*

CONSERVE

WATER

INDEX

SR. No. CONTENTS

1. RERORT
2. DESIGN CALCULATIONS
3. FINAL ABSTRACT OF COST
4. WATER SUPPLY
5. SEWERAGE
6. STORM WATER DRAINAGE
7. ROADS
8. STREET LIGHTING
9. HORTICULTURE
10. MAINTENANCE CHARGES AND RESURFACING OF ROADS
11. DESIGN DATA OF ROADS
12. DESIGN DATA OF WATER SUPPLY
13. DESIGN DATA OF FLUSING PIPELINE
14. DESIGN DATA OF SEWERAGE
15. DESIGN DATA OF STORM WATER DRAINAGE
16. LAYOUT DRAWINGS

PROJECT REPORT/ ESTIMATE FOR PROVIDING WATER SUPPLY, SEWERAGE, STORM WATER DRAINAGE, ROADS, STREET LIGHTING AND HORTICULTURE IN RESPECT OF 14.209 ACRES (113K-13M-4S) FALLING IN THE REVENUE ESTATE OF VILLAGE DHORKA, SECTOR 95, G.M.U.C. (HR)

REPORT

THE HARYANA GOVERNMENT HAS PREPARED A MASTER PLAN FOR DEVELOPMENT OF D.D.J.A.Y. AFFORDABLE PLOTTED COLONY AN OVER AREA OF 14.209 ACRES (113K-13M-4S) FALLING IN THE REVENUE ESTATE OF VILLAGE DHORKA, SECTOR 95, G.M.U.C. (HR) BEING DEVELOPED BY - MRS. ANJU CHILLAR IN COLLABORATION WITH LANDMARK APARTMENTS PVT. LTD.

WATER SUPPLY

1 Source

The source of water supply in this area is tubewells at present as the underground water is potable and fit for human consumption. Moreover water available at reasonable depth. The average yield of tubewell with 40-50 ft strainers will be about 25,000 litre per hour. The recharging of underground water table in the belt is stated to be good. However still we shall resort to rain water harvesting system to keep up the recharging system. The numbers of tubewells required for the above area has been worked out and the tubewells will be bored in tune with growth of demand to avoid absolence of the tubewells. The ultimate requirement of tubewells includes provisions of 10% stand by.

2 Design

The scheme has been designed for approved population of 4428 persons. The rate of water supply per head per day has been taken as 172.5 litres as per Haryana norms. In addition to above necessary provision of water for Horticulture have been taken in to account for calculating the maximum quantity of water requirement.

For LANDMARK APARTMENTS PVT. LTD.

Authorised Signatory

Ar. VIKAS AHLAWAT
CA/2013/59929



3 Pump Chambers and Pumping Machinery

It is proposed to equip each tubewell with an electricity driven set ejecto type or submersible pump capable of delivering of 25,000 litre per hour. It is also proposed to equip required Nos pumping sets with stand by diesel engines / gen set engines for operation during failure of electricity.

4 Under Ground Storage

Underground storage tank provision has been made for 420 Kl Capacity in two compartments (210 KL each), which caters for the domestic as well as for fire fighting requirements.

5 Boosting Station

The boosting station is being planned UGSR catering to the above requirement.

6 Distribution System

The distribution system for this development has been designed to Supply @ 172.5 litre per head per day @ 3 times the average rate of flow on Hazen William formula. Necessary provision for laying CI/DI pipes conforming to relevant IS standards along with valves and specials has been made in the project.

7 Rising mains

Rising mains from GMDA water main or sector road to water works has also been proposed and provision has been made in this estimate.

8 Sewerage

The sewer lines have been designed for 3 times average DWF in relation to the water supply demand assuming that 80 % of the water supply shall find its way in to the proposed sewer. SW/DWC pipe have been proposed and designed to run half full. The sewers have been designed on 0.7 M per second minimum velocity.

9 Storm water Drainage

The storm water drainage is being designed to carry 6.25mm rainfall per hour. Also suitable provisions are contemplated in our scheme to ensure better recharging of underground water table. R.C.C. Hume pipes with minimum 400 mm dia is proposed in this area.

10 Roads

The roads have been planned 9m wide. The following Specifications have been adopted which are reproduced below :

- (1) 250 mm GSB
- (2) 250 mm WMM
- (3) 50 mm thick B.M
- (4) 30 mm BC

The above construction shall be done on well compacted sub grade as per specifications. Complete work will be carried out as per MORTH specification, IRC guide lines or HUDA specification, which ever applicable.

11 Street lighting

The provision has been made on lump sum basis.

12 Horticulture

The usual provision of road side plantation of tree guards has been made for all roads. The parks shall be developed by providing lawns etc.

13 Specifications

The works will be carried out in accordance with the standard specification of P.H. Department as laid down by GMDA & Haryana Government.


14 Rates

Estimate for providing services in this pocket has been prepared on the recent market rates.

15 Cost

The total cost of development in this project including various P.H. and B & R services works out to be Rs. ~~1533.62~~ Lac.

The cost per gross acre for the phase works out to be Rs. ~~107.93~~ lac which covers the provision of services like water supply, sewerage, storm water drainage, roads, street lighting and plantation including maintenance thereof as well as escalation, administrative departmental and unforeseen charges.


Ar. VIKAS AHLAWAT
CA/2013/59929



For LANDMARK APARTMENTS PVT. LTD.


Authorised Signatory

DESIGN CALCULATION

WATER REQUIREMENT

A.				
1.1	No. of plots	246	Nos.	
	Occupancy @ 18 person/plot	4428.0	Person	
		4428	Say	
	Water requirement @ 172.5 ltr/person	763830	Liters	1.1
<i>or 763.83 KL</i>				
1.2	Commercial area	<i>0.568 Area</i> 2299.74	Sq. Mtr.	
	Occupancy @ 3 sq.mtr./ person	<i>@ 3200 ltr / Area</i> 766.58	Person	
	Visitor population @ 90% of total population	<i>18176 ltr</i> 689.92	Person	
	Staff population @ 10% of total population	76.66	Person	
	Water requirement			
	Visitor 15 ltr/person	10348.84	Liters	
	Staff 45 ltr/person	3449.60	Liters	
	Total	<i>18176</i> 13798.41	Liters	1.2
1.3	Community Hall	<i>1.426</i> 5769.11	Sq. Mtr.	
	Occupancy @ 3 sq.mtr./ person	<i>@ 2500 ltr per Person</i> 1923.04	Person	
	Visitor population @ 90% of total population	5192.20	Person	
	Staff population @ 10% of total population	<i>35650</i> 192.30	Person	
	Water requirement			
	Visitor 15 ltr/person	7782.99	Liters	
	Staff 45 ltr/person	8653.67	Liters	
	Total	<i>35650 ltr</i> 86536.65	Liters	1.3
Total Water Requirement of "A" (1.1+1.2+1.3)		864165.06	Liters	A
B.	For E.S.S	5000.00	Liters	
C.	MTC, Staff & Guard etc.	<i>588264 or 58.83 KL</i>		
	Considering water requirement for mtc, Staff + Guard etc. L.S.	20	Person	
	Water requirement 45 ltr/person	900	Liters	
Total Water Requirement (A+B+C)		870065.06	Liters	
		870	KLD	

II FIRE DEMAND				
	For U.G.T. i.e. Population	4428.0	Person	Residential
	(100/(P/1000) ^{0.5})/3 (Where P is population)	70.14	KL	
	Total	70.00	KL	
	Say	70	KL	

III Garden Irrigation Requirement				
A	Area 4564.854 m ² x 8 Ltr. <i>6.17 ltr</i>	36518.83	KLD	
TOTAL		36.52	KLD	
Say		36	KLD	

(B) Area Under Road out of 14.209 Area = 1.76 Hecctar
 Therefore daily water Requirement = 1.76 x 5000 = 8800 ltr or 8.80 KL
 For Sweeping of Roads

IV	STORAGE	825	825	
	Total Water Requirement (Excluding Fire Demand)	870.00	870	KLD
	Hence Domestic Water requirement (67%)	552.75	583 555	KLD
	Hence Flushing Water requirement (33%)	272.25	287 272+37	KLD
	Domestic Water Storage @ 60%	333	349.74	KLD
	Flushing Water Storage @ 60%	185.40	172.26	KLD
It is proposed to construct underground tanks capacity 350 KL for domestic use+ 70 KL for fire fighting; total 420 KL in two compartments of 210 KL each and 172 KL for non potable water in STP in two compartment. 200				
	Total Capacity of UGT	420		KLD

V.	TUBEWELL			
a	Yield	25	KL/Hr.	
b	Working hrs. per day	8	Hr./Day	
c	Total water demand	555	583	KLD
d	No. of tube well reqd. (Water demand/discharge/hr. working per day)	2.92	Nos.	
e	Add 5% extra.	2.77	0.15	Nos.
	Say	3	Nos.	

In Proposed development Water is to be supplied by GMDA. However, it is proposed to install three no. bore well for augmentation / standby purpose and provision has also been taken in the estimate due to non availability of water but after getting the approval from competent authority. The requirement of flushing water is to be met from treated water from STP.

i)	Pumping machinery for Tube well			
a	Gross working head	80	Meter	
b	Average fall in S.L.	2	Meter	
c	Depression head	6	Meter	
d	Friction loss in main	10	Meter	
	Total	98	Meter	Say 100 mtr.
e	Discharge	$\frac{25000 \times 100}{60 \times 60 \times 75 \times 0.60} =$	25000	LPH
			6.94	LPS
	Say		7.00	LPS
f	Horse power (HP = (7 x 98) / (75 x 0.60))	15.24	15.43	H.P.
		15	17.50	Say

It is proposed to provide 2 no. (1W+1S) Pumping set of 7 lps discharge at 100 mtr. Head.

ii)	Boosting machinery for domestic water for UGT	555		
	Total Water Requirement	583		KLD
	Pumping per hour @ 8 hr. pumping / day	69.375	72.88	KL/Hr.
		34.68	20.24	LPH LPS
	Considered 2W+1SB pumps	578 LPH.	10.12	LPS
	Say		10.0	LPS
	Gross working head	Say = 600 LPH.		
a	Suction lift	7	Meter	
b	Friction loss in mains & specials	6	Meter	
c	Clear Head required	30	Meter	
d	Residual	2	Meter	
	Total	43	50	Meter
	Say	45	50	Meter
e	Horse power (HP = (10 x 50) / (75 x 0.60))	45	10.0	H.P.
		10.0	11.1	Say

It is proposed to provide 3 no. Pumps (2W+1SB), Flow of each shall be 10 lps at 50 mtr. Head in UGT.

iii) Boosting machinery for Flushing water at STP				
	Total Water Requirement (Flushing + Irrigation)	309	323	KLD
	Pumping per hour @ 8 hr. pumping / day	38.62	40.38	KL/Hr.
		10.72	11.22	LPS
	Say	642 LPM.	11.0	LPS
	Gross working head	Say = 650 LPM.		
a	Suction lift		7	Meter
b	Friction loss in mains & specials		6	Meter
c	Clear Head required		30	Meter
d	Residual		2	Meter
	Total	45	50	Meter
	Say	45	50	Meter
e	Horse power (HP = $(11 \times 50) / (75 \times 0.60)$)	45	12.22	H.P.
		11.0	12.50	Say

It is proposed to provide 2 no. Pumps (1W+1SB), Flow of each shall be 11 lps at 50 mtr. Head in STP.

iv) DG Set for Plumbing				
	DG Set requirement			
	Submersible Pump (4x15)	45	15	HP
	Domestic Pump (2x10)		20	HP
	Flushing Pump (1x12)	12.50	12.50	HP
	For External electrification wiring.		5	HP
	Total Pump Load	82.50	52	HP
	Total DG capacity	85	40	KVA

Hence it is proposed to provide 1 no. DG set of 40 KVA capacity.

v) FLOW TO SEWAGE TREATMENT PLANT				
	Total water Requirement = 583 KLD for Domestic + 287 KLD for flushing	Dom & Flushing water		825.00
		870.00	870.00	KLD
a	80% of total Domestic water demand = 80% of 583 KLD	825 KLD	466.40	KLD
b	80% of total Flushing water demand = 80% of 287 KLD	660.00	229.60	KLD
	Total	330.00	696.00	KLD
	Say Proposed STP Capacity	693 kL.	700	KLD