

FIRE LAYOUT PLAN

PLUMBING & FIRE SERVICES LEGEND :	
	SEWER MANHOLE WITH 5000 S.F.A.C. MANHOLE COVER.
	STORM WATER MANHOLE WITH 5000 S.F.A.C. PERFORATED MANHOLE COVER.
	CATCH BASIN (450 x 450) MM WITH PERFORATED MANHOLE COVER
	CATCH BASIN (600 x 600) MM WITH PERFORATED MANHOLE COVER
	STORM WATER MANHOLE (900 x 900) MM WITH PERFORATED MANHOLE COVER.
	SEWER MANHOLE (600 x 600) MM
	SEWER MANHOLE (800 x 800) MM
	GULLY TRAP (300 x 300) MM
	EXTERNAL SW SEWER LINE (DIA AS / DESIGN CHART)
	EXTERNAL RCC STORM WATER LINE (DIA AS / DESIGN CHART)
	1500 DI MUNICIPAL WATER SUPPLY LINE
	GI DOMESTIC WATER SUPPLY LINE
	GI FLUSHING WATER SUPPLY LINE
	HOPE GARDEN IRRIGATION WATER SUPPLY LINE
	GARDEN HYDRANT WITH CHAMBER (300x300) MM
	RECHARGE PIT, 3000 MM DIA
	DESILTING CHAMBER (1000 x 2000)MM
	4 WAY FIRE BRIGADE INLET CONNECTION FOR FIRE TANK
	2 WAY FIRE BRIGADE WITHDRAWAL CONNECTION FROM FIRE TANK, PIPE DIA 1500

DDP (M) MEMBER BPAC

S.P. (H) S.P. (G) S.P. (H) Chairman BPAC

Sanctioned
MEMO NO.:
DATED:

TO BE READ WITH T.O. OFFICE

Architect

Ram Avtar Bassi
JD(HQ)



PROJECT TITLE	
PROPOSED BUILDING PLANS OF AFFORDABLE GROUP HOUSING COLONY OVER AN AREA MEASURING 9.9625 ACRES (LICENSE NO. 131 OF 2023 DATED 23.06.2023) IN REVENUE ESTATE OF VILLAGE KUMAR, DISTRICT GURUGRAM, HARYANA, BEING DEVELOPED BY TATVASTU REALTY PRIVATE LIMITED (FORMERLY KNOWN AS SEDULOUS REALTECH PVT. LTD.)	
LC-4982	OWNERS' SIGNATURE
ARCHITECT'S SIGNATURE	
DRAWING TITLE	
EXTERNAL SITE PLAN FIRE LAYOUT	
ARCHITECT	NORTH
GANGA REALTY - DESIGN TEAM	
GANGA REALTY Vastu Tower, Gold Course Road Gurgaon, Haryana	
DATE	NOVEMBER, 2022
SCALE	1:550
DEALT	DA
CHECKED	NKM
DWG. NO. P-105	

Checked and found ok for Public Health
(Internal) Service only subject to comments in
forwarding letter No. 2.67.717, D.V. 2.5.1.23

Sanctioned
MEMO NO.:
DATED:

Architect

Ram Avtar Bassi
JD(HQ)

24.0M WIDE SECTOR ROAD

OTHERS LAND
(LICENCED)

This is to certify that the project will be constructed on
Mivan (Aluminium Formwork) construction technology
which is more effective & stable design strategy and same
is as per IS-456:2000, Section
32.1 & 32.2 whereas M. Minimum Thickness of all
walls shall be 100 mm in RCC.

12.0M WIDE SERVICE ROAD