



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Govt. of Haryana under taking)

Office of the

Chief General Manager (OP) DHBVN, Delhi-35



Off. 011-28312877

011-28313780

Fax 011-28312866

To

The SE 'OP' Circle
DHBVN, Gurgaon

Memo No. Ch-2) WD-1 DAG-1678/Gen Dated: 11/9/14

Sub:

Sanction of 4471KW load with CD 4968KVA to M/s Jan Priya Buldestate Pvt. Ltd., Sector-77, Village Sikhopur, Gurgaon, applied vide A&A No. 45606/BS/DS dated 30.10.2013.

As recommended vide your office memo No. Ch-8/PC-GC-406/MNS dated 07.07.2014, sanction is hereby accorded for sanction of load 4471KW with CD 4968KVA to M/s Jan Priya Buldestate Pvt. Ltd., Sector-77, Village Sikhopur, Gurgaon, on 11KV supply pressure and on HT/BS/DS tariff supply through proposed 11 KV independent feeder emanating from 66KV Substation Old Power House, Manesar subject to fulfillment of the following conditions:-

1. Apart from other provisions, instruction of sales manual specifically no.1.21 & 4.2 shall be applicable in this case for which action needs to be taken in first instance accordingly.
2. All other formalities as required as per instructions issued/adopted by Nigam time to time shall be completed.
3. Metering equipments including CTs & PT's of matching capacity as per specifications/ design of Nigam shall be provided and Metering equipment of appropriate capacity shall be installed at S/Stn. and metering room shall be provided at the main entrance gate of the premises as per instructions issued vide S. C No. D-11/2005 dated 13-7-05 and Sales Instruction No. 7/2009 dated 02.09.2009 and Installation must be got inspected by CEI before releasing the connection.
4. No. applicant senior to the instant applicant/ consumer is waiting sanction of load/extension of load.
5. Full advance Consumption security and other applicable charges be recovered from the applicant before further processing the case as per Sales Circular No. D-26/2011.
6. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card, driving license etc., shall be obtained from the applicant/ consumer. The consumer will be submitted documentary proof in support of ownership of land before taking further action.
8. Necessary clearance certificate from various Govt. Department i.e. CEI, Pollution Control Board etc. shall be taken.
9. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.

FOR UMANG REALTECH (P) LTD.

Rakesh

Authorised Signatory

10. The Sanctioned load is, required, to be built-up, within six months from the release of this connection in terms of SMI No. 1.21 and consumer should give undertaking to this effect. If the consumer does not avail the full revised sanctioned load within above period of six months then the revised A&A forms for the availed load verified and accepted on the basis of test report may be sent to this office/competent authorities for acceptance/sanction.
11. Regarding share cost of main sub-station, applicant shall comply with the formalities as per prevailing Instructions of the Nigam as well as instructions issued from time to time.
12. Since HT broacher contains old instructions an additional affidavit shall be obtained from the consumer to abide by the provision of the Electricity Act. 2003 and instructions issued by the Nigam there upon from time to time.
13. The tariff shall be charged from the individual consumers if any in accordance with HERC regulations and sale instructions/circular issued by the Nigam from time to time. (Only for bulk – Domestic supply)
14. NOC may be obtained from HVPN before release of said load from 66KV Sub-station, if required.
15. Two No. witnesses on A&A page No. 13 should be consumers of the Nigam preferably before taking further action
16. Sales manual instructions, instructions and sale circulars invoke as well as issued/amended from time to time will be applicable to the applicant.
17. The compliance of Nigam's instructions issued from time to time which are not incorporate in the above are required to be complied with by the consumer.
18. Before releasing the said load, you must adhere the instruction of Nigam regarding inadequacy.
19. The load will be released after providing additional 12.5/16MVA (T-III T/F) at 66KV S/Stn. Old Power House, Manesar.
20. The load will be released after erection of 11KV independent feeder by the consumer at his cost.

The A&A form along with others concerned papers as received are returned herewith duly accepted by the under signed in view of sales Instruction No. 48/2006 and instruction issued by C.G.M/P&D DHBVN Hisar vide his office memo No.Ch-161/DD-169 dated 11.04.2007.


DA/As above


Chief Engineer (OP),
DHBVN, Delhi.

CC:-

1. Xen 'OP' Division, DHBVN, Manesar.
2. M/s Jan Priya Bulldestate Pvt. Ltd., Sector-77, Village Sikhopur, Gurgaon.

For UMANG REALTECH (P) LTD.



Authorised Signatory