



UTTAR PRADESH POWER CORPORATION LIMITED
(A Power Distribution & Retail Supply Utility, Govt. of U.P.)
Chief Engineer/Commercial, Shakti Bhawan, Sec-6 Panchkula.
Phone: 0172-2564205 & Fax: 0172-2583722
e-mail: cgmcommercialuppc@gmail.com Web Site: www.uppc.com

From

Chief Engineer/ Comm.
UPPC, Panchkula.

To

The SE 'OP' Circle,
UPPC, Jhajjar.

Memo No. Ch-07/SS-403/641/Lay.P/METL/CE/C-1
Dated: 25.04.2017

Subject:-

Memorandum of revised electrification layout plan for industrial colony area vide License No. 19 of 2011, 6 of 2012, 7 of 2012 and 8 of 2016 being developed by M/s Model Economic Township Ltd. (METL) (formerly Reliance Haryana SEZ Ltd.).

Please refer to your office memo no. Ch- 78/CC-136 dated 13.03.2017 vide which memorandum of revised electrification layout plan for industrial colony area vide License No. 19 of 2011, 6 of 2012, 7 of 2012 and 8 of 2016 being developed by M/s Model Economic Township Ltd. (METL) (formerly Reliance Haryana SEZ Ltd.) for setting up of Industrial Township was sent for approval.

As recommended by your office vide memo referred above, the proposal for electrical Layout plan of M/s Model Economic Township Ltd. (METL), Jhajjar having 365 acres land for which necessary license has been given by Director, Town & Country Planning Department, Haryana has been considered in view of the technical feasibility committee report held on dated 29.03.2017 and approved by the WTDs in circulation on 22.04.2017 for a load of 88.07 MVA on 220 KV level to be fed from at 220 KV Badana and 400 KV Sub-station Farukh Nagar through 220 KV double circuit line as deposit work. The firm will also deposit the cost of 2 nos. 220 KV bays to terminate 220 KV D/C line at both the feeding end sub-stations alongwith requisite charges as per instructions. The site of 220 KV Sub-Station shall be located at the load centre on left side of Jhajjar - Gurugram Road.

Also, the approval of electrification plan is subject to fulfillment of all terms and conditions of S.C. No. U-15/2015, U-31/2016, U-33/2016 & 35/2016 along with the following:-

1. The developer will erect and install 33/11 KV Sub-Stations and lines as per the load. Further, will install distribution transformers as per 80% loading condition of standard quality as per Nigam specification to cater the total load requirement of Township.
2. Inspection charges as per HERC norms be got deposited from the developer, if the work executed under Self Execution Scheme.
3. The Developer / Colonizer shall deposit the cost of bays and other charges with HVPN / UHBN as per the instructions of respective Nigam.
4. The developer / colonizer must install/erect whole Electrical Infrastructure as per Nigam's design, drawing & specifications within a period of five years after approval of electrification and hand over the system to the Nigam/RWA as applicable.

For Model Economic Township Limited

Authorized Signatory

115

- DA/Files and MoM

Cc

- End of 953

dl. 2

Ends: No. 85 / CC-136 D 11-5-17

Copy of the above referred to in the

[illegible]

...for further necessary action.

Circle for further information For Model Economic Township Limited

5-10-72/4
S. J. (or) C. J.
U. S. N. A. B. A. B.

Authorized Signatory

S/P 5/Dir Thajjar

The following were present:-

1. Sh. Naresh Sardana - Director (T-I), UHBVN, Panchkula.
2. Sh. S.K. Chhillar - Director (T-II), UHBVN, Panchkula.
3. Sh. Raj Pal - CE (OP) UHBVN, Rohtak.
4. Sh. M.S. Dahiya - CE/Commnl., UHBVN, Panchkula.
5. Sh. Rakesh Jolly - CE/Planning, HVPNL, Panchkula.
6. Sh. R.K. Sharma - CE/PD&C, UHBVN, Panchkula.
7. Sh. Kulbir Singh - CE/TS, HVPNL, Panchkula.
8. Sh. A.K. Singla - SE/TS, HVPNL, Rohtak.
9. Sh. H.P. Sharma - SE/Commnl., UHBVN, Panchkula.
10. Sh. T.K. Sharma - SE/PD, UHBVN, Panchkula.

The technical feasibility for approval of electrification plan of M/s Model Economic Township Ltd for a load of 88.07 MVA to be released from 220 KV GIS S/Stn. constructed by M/s METL under Self Execution Scheme to be fed from 220 KV Badana and 400 KV S/Stn. Farukhnagar through 220 KV double circuit line as a deposit work. The firm will also deposit the cost of 2 nos. 220 KV bays to terminate 220 KV D/C line at both the feeding end S/Sins. alongwith requisite charges as per instructions. The site of 220 kv S/Stn shall be located at the small distance on left side of Thajjar, Gurugram Road.

12/11

Director (I-I) UHBVN, Pkl. Director (I-II) UHBVN, Pkl. CE (OP) UHBVN RTK CE/Comm. UHBVN, Pkl. CE/Pig. UHBVN, Pkl. HVPNL, Pkl.

~~SECRET~~
UHBVN, PKI

CE/TS
HVPN, PKI

SETS
HMPN, RTK

UBVN, PK

SE/COMINT
UFGVN, PKI

DATE: 04/29/06 12:51 PM
 CC: [redacted]
 TO: [redacted]
 FROM: [redacted]
 SUBJECT: [redacted]
 UNDER THE DIVISION OF [redacted]
 RECOMMENDATION: [redacted]

For Model Economic Township Limited

117

Authorized Signatory