



Amme 2-1

DAKSHIN HARYANA BIJLI VITRAN NIGAM
(A Power Distribution & Retail Utility, Govt. of Haryana)
An ISO 9001:2008 Compliant Utility, CIN: U99999HR1999SGC034165
O/o Chief General Manager /Commercial, DHBVN, Hisar
Regd Office Vidyut Sadan, Vidyut Nagar, Hisar-125005(Haryana)
Ph: 01662-223093, Fax No. 01662-223153
Website: - www.dhbvn.org.in E-Mail: cgmcommercialdhbvn@gmail.com

To

The CE/OP
DHBVN, Delhi.

Memo No. Ch-10/SE/C-30L-131

Dated 12-4-16

Subject: - Sanction of EOL from 500 KW to 23500 KW to M/s Ramprastha Sare Realty Pvt. Ltd. Sec-92 (Near vill. Mevka) Gurgaon on 33 KV supply pressure applied vide A&A No. 55161/ HT/ BS (DS) dated. 28.10.14 under 'OP' S/Divn. DHBVN, F/Nagar----approval of partial 3000 KW load on 11 KV supply pressure.

Please refer to your office memo No. Ch-6/WO-DRG-1742/GGN dated 22-09-2015 on the subject cited matter above, followed by subsequent correspondences received from your office and SE/OP, Gurgaon vide which the observations pointed out by this office has been got duly attended from the developer and submitted thereof to this office.

In view of SI No. 21/2015, approval is hereby accorded for electrification scheme of M/s Ramprastha Sare Realty Pvt. Ltd. Sec-92 (Near vill. Mevka) Gurgaon under single point supply for extension of load from 500 KW to 23500 KW (or 26111 KVA) under bulk domestic category on 33KV supply pressure to be fed from proposed 220/33KV S/Stn. Sec-95, Gurgaon, through 2 No. 33 KV independent feeders using 2Rx 33 KV U/G XLPE cable in view of maximum ceiling of 25 MVA load on 33KV level as per HERC Electricity Supply Code Regulation, 2014.

The electrification plan has been examined from the aspect of sufficiency of infrastructure with respect to the ultimate load only and not from any design / specification aspect, in accordance with SI No.21/2015.

In addition to above, the extension of load of 500 KW to 23500 KW (26111 KVA) under bulk supply domestic category is hereby sanctioned as per SC No. D-20/2011 subject to the conditions as under:-

1. The developer has proposed to install 33/0.4 KV T/Fs of capacity i.e. 5 x 3200 KVA + 1x 2200 KVA + 2 x 2000 KVA + 4 x 1600 KVA and 1x 5000 KVA open to sky.

SDO/2016

59

2. The ultimate load of 23500 KW (or 26111KVA) on 33 KV level has been approved by the Committee, subject to laying of two no. 33KV independent feeders at the cost of the consumer from the proposed 220 KV S/Stn Sec-95 to be constructed by HVPN.
3. Guidelines given in the SI No.-21/2015 may be complied with strictly.
4. An undertaking shall be taken from the developer that the land earmarked for S/Stn./Switching/Stn. shall not be diverted for any other use.
5. An undertaking be obtained from the consumer that the technical feasibility shall be examined afresh every time the consumer applies for extension of load.
6. SE/OP, DHBVN Faridabad should personally ensure that the BG of independent feeders and internal infrastructure deposited by the developer is as per Nigam instructions and commensurate with the ultimate load.
7. The developer will deposit the share cost as per the instructions of HVPN.
8. The developer will enter into tripartite agreement with HVPN and DHBVN.
9. No applicant, senior to the instant applicant/ consumer is waiting for sanction of load / extension of load.
10. Processing charges, Consumption security & other applicable charges be recovered from the developer as per Nigam Instruction.
11. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card, driving license etc. shall be obtained from the applicant / consumer.
12. The developer will submit documentary proof in support of ownership of land.
13. Non- judicial stamp worth Rs. 3/- on the left corner of A&A be got affixed by the SDO before taking further action.
14. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.
15. The developer shall comply with the instructions of the Nigam issued by this office time to time.
16. The HT brochure may contain old instructions, as such an additional affidavit be obtained from the consumer to abide by the provision of the Electricity Act 2003 and complying of all the instructions of SMI & Sales Circular issued as well as amended by the Nigam from time to time before release.
17. Necessary clearance from various Govt. Department i.e. CEI, Pollution Control Board etc. shall be taken.
18. The tariff shall be charged from the consumer in accordance with tariff schedule approved by HERC.

19. The developer shall erect 2 No. 33 KV independent feeders using 2RxU/G XLPE cable as per specification and design of the Nigam.
20. Inspection of material to be used will be got carried out from DHBVN Authorities and inspection charges @ 1.5% of the estimated cost of work shall be paid by the applicant to the Nigam.
21. All other formalities as required as per instruction issued/adopted by Nigam time to time shall be completed.
22. The developer shall apply for single point connection as per HERC regulations.
23. Metering equipments including CTs of matching capacity as per specifications / design of Nigam shall be provided at feeding S/Stn. as per Nigam instructions.
24. The partial load of 3 MW on 11 KV level from 25/31.5 MVA, 66/11KV, T-2, Power T/F at 66KV S/Stn Harsaru was allowed by the Committee as a stop gap arrangement subject to furnishing of undertaking and Bank Guarantee as per instructions.
25. Protection scheme to be provided on independent feeders at the applicant's end for obtaining supply at 33KV level from 220/33 KV S/Stn. Sector-95, Gurgaon be got cleared from M&P wing of both DHBVN and HVPN authority before energization.

This issues with the approval of DIR/OP, DHBVN, Hisar at NP-8, of File No. SOL-131.

DA / Consumer case files.

[Signature]
12/4/2016
CE/Commercial
DHBVN, Hisar

CC to:-

1. The PS to Director/OP, DHBVN, Hisar for kind information of Director please.
2. SE/OP, DHBVN, Gurgaon.
3. XEN/OP, DHBVN, Manesar.
4. SDO/OP, Sub-Division, F/Nagar.
5. M/s Ramprastha Sare Realty Pvt. Ltd. Sec-92 (Near vill. Mevka) Gurgaon.