

DHBVN**DAKSHIN HARYANA BIJLI VITRAN NIGAM****(A Power Distribution & Retail Supply Utility, Govt. of Haryana)**
An ISO 9001: 2008 Compliant Utility, CIN: U99999HR-1999SG034165**Chief Engineer/Commercial, DHBVN, Hisar,****Regd. Office: Vidyut Sadan, Vidyut Nagar, Hisar-125005 (Haryana)****Phone No. 01662-223093, Fax No. 01662223153****Website: dhbvn.org.in****E-Mail: cecommercialdhbvn@gmail.com**DHBVN

To

SE/OP,
DHBVN, Gurugram-II

Memo No. Ch-8/SE/C-EP-240

Dated 21/6/2017

Sub: -

Approval for Sanction for electrification scheme with ultimate load of 13.50 MW or 15.00 MVA with partial load 900 KW or 1000 KVA to M/s Countrywide promoters Pvt. Ltd., village-Basai Sector-37D, Gurugram under SDO "CCC" Kadipur S/Divn., DHBVN, Gurugram.

Please refer to your office memo No. Ch. 133/LS-1 dated 20.12.2016 on the subject cited matter above.

Approval of electrification scheme of M/s Countrywide promoters Pvt. Ltd., village- Basai Sector-37D, Gurugram under SDO "CCC" Kadipur S/Divn., DHBVN, Gurugram with ultimate load 13.50 MW or 15.00 MVA and sanction of partial load 900 KW or 1000 KVA under HT Bulk Domestic Supply Category falling under SDO/OP, CCC, Kadipur, S/Divn., Gurugram is hereby accorded subject to compliance of the terms and conditions given as under:-

1. The developer shall create 33/11 KV S/Stn. with installed capacity 2X10 MVA, 33/11KV Power Transformers. Further, the developer shall install 10X1600 KVA + 3X1000 KVA + 1X630 KVA, 11/0.4 KV dry type Transformers. i.e. total capacity of 19630 KVA. Since the developer has proposed to installed dry type distribution T/Fs so, from safety aspect an NOC in this regard may be obtained from Chief Electrical Inspector, besides ensuring compliance of all safety measures by SE/Op, Gurgaon.
2. The electrification scheme of M/s Countrywide promoters Pvt. Ltd., village- Basai Sector-37D, Gurugram under SDO "CCC" Kadipur S/Divn., DHBVN, Gurugram with ultimate load 13.50 MW or 15.00

MVA under HT bulk Domestic Supply category falling under SE/Op under , DHBVN, Gurugram-II shall be fed on 33KV level from proposed 220/33KV S/Stn Sector-99, Gurugram through 33KV independent feeder with double run 3CX300 mm² U/G XLPE Cable (at the cost of the applicant). Further, load of 1MVA is allowed at 11KV level from 66 KV S/Stn Sec-10A subject to augmentation of capacity from 2X25/31.5 MVA + 12.5 /16 MVA, 66/11KV Power T/Fs to 3X25/31.5 MVA Power T/Fs, through 11KV independent feeder with 3CX300 mm² U/G XLPE Cable.

3. The applicant shall switch over his connection from 11 KV to 33 KV as per Nigam Sales Circular No. D- 19/2015 . On switch over from 11 KV to 33 KV , the dismantled 11 KV system shall become the property of DHBVN
4. Protection scheme to be provided on independent feeder at the applicant's end for obtaining supply at 33KV level be got approved from the M&P wing of both DHBVN & HVPN.
5. Guidelines mentioned in Sale Instruction no.- 21/2015 should be duly complied with.
6. Complaint centers shall be constructed by the applicant as per Nigam instructions No. P&D 9/2011.
7. An undertaking be obtained from the consumer that the technical feasibility shall be examined afresh every time the consumer applies for extension of load.
8. The applicant either deposit ACD corresponding to ultimate load in cash in one go or ACD corresponding to partial load in cash and ACD for balance of ultimate load in the shape of BG.
9. SE/OP, DHBVN Gurgaon should personally ensure that the BG of independent feeder and internal infrastructure deposited by the applicant is as per Nigam instructions and commensurate with the ultimate load prior to release of load.
10. CEA guidelines and IE rules regarding Safety precaution should be adhered to for connecting the electrical system.
11. The applicant will enter into tripartite agreement with HVPN and

12. No applicant, senior to the instant applicant/ consumer is waiting for sanction of load / extension of load.
13. Processing charges, Consumption security & other applicable charges be recovered from the applicant as per Nigam Instruction.
14. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card, driving license etc. shall be obtained from the applicant / consumer.
15. The applicant will submit documentary proof in support of ownership of land.
16. Non- judicial stamp worth Rs. 3/- on the left corner of A&A be got affixed by the SDO before taking further action.
17. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.
18. The applicant shall comply with the instructions of the Nigam issued by this office time to time.
19. The HT brochure may contain old instructions, as such an additional affidavit be obtained from the consumer to abide by the provision of the Electricity Act 2003 and complying of all the instructions of SMI & Sales Circular issued as well as amended by the Nigam from time to time before release.
20. Necessary clearance from various Govt. Department i.e. CEI, Pollution Control Board etc. shall be taken.
21. The tariff to be charged from the residents should in accordance with tariff schedule approved by HERC.
22. For the creation of S/Stn. / transmission lines & before erection of major items, inspection will be got carried out from DHBVN / HVPN Authorities. The inspection charges @ 1.5% of the estimated cost of work shall be paid by the applicant to DHBVN / HVPN as the case may be.
23. The applicant will deposit the share cost as per the instructions of HVPN, if required.
24. The applicant shall erect underground HT lines & other infrastructure as per specification and design of the Nigam.

25. All other formalities as required as per instruction issued/adopted by Nigam time to time shall be completed.
26. Metering equipments including CTs of matching capacity as per specifications / design of Nigam shall be provided at feeding S/Stn. as per Nigam instructions.
27. The applicant shall comply with provision of Haryana Renewable Energy Department regarding installation of solar Photovoltaic Power Plant applicable from time to time.

This issues with the approval of Director/OP, DHBVN, Hisar at NP-12 of file no. EP-240

He
CE/Commercial,
DHBVN, Hisar

CC to:-

1. PS to Director/OP, DHBVN, Hisar for kind information of Director please.
2. CE/OP, DHBVN, Delhi.
3. CE/Planning, HVPN, Panchkula.
4. CE/TS, HVPN, Hisar
5. SE/TS, HVPN, Gurgaon.
6. SE/NCR, Planning, HVPN, Gurgaon
7. XEN/OP, City Division, DHBVN, Gurugram.
8. SDO/OP, CCC" Kadipur S/Divn., DHBVN, Gurugram
9. M/s Countrywide promoters Pvt. Ltd., village- Basai Sector-37D, Gurugram.