

|          |                     |
|----------|---------------------|
| LEGENDS: |                     |
|          | EXHAUST AIR DUCT    |
|          | FRESH AIR DUCT      |
|          | PRESSURIZATION DUCT |
|          | AXIAL FLOW FAN      |
|          | FRESH AIR GRILLE    |
|          | EXHAUST AIR GRILLE  |

FIRE SUBMISSION DRAWING

PROJECT  
PROPOSED BUILDING PLAN OF  
COMMERCIAL COLONY AREA  
MEASURING 3.99 ACRES (LICENCE NO.  
119 DATED 05-06-2023) FALLING IN  
SECTOR-90, GURUGRAM BEING  
DEVELOPED BY NORTH STAR TOWERS  
PVT. LTD., MATRIX BUILDWELL PVT. LTD.,  
IN COLLABORATION WITH NORTH STAR  
APARTMENTS PVT. LTD. (NOW KNOWN  
AS SS GROUP PVT. LTD.)

MEP CONSULTANTS



UDAYAN CHAUDHARY & ASSOCIATES PVT. LTD.  
408/0, GROUND FLOOR, C/F PARK,  
DELHI-110001  
E-Mail : udayan@uayandesign.com  
Website : www.uayandesign.com



ACPL Design Ltd. Registered and the Filing System is  
Approved by the Ministry of PwD, Government of India

|                                         |            |            |
|-----------------------------------------|------------|------------|
| THANKS TO                               | CHECKED BY | DATE       |
| LK                                      | AG         | 15.12.2023 |
| VENTILATION LAYOUT<br>FOURTH FLOOR PLAN | VENT -08   |            |

For SS Group Pvt. Ltd.  
Authorised Signatory  
OWNER'S SIGNATURE



# FOURTH FLOOR

NOTE :-  
Multiplex Supply air duct shall be used for smoke extract air in case of Fire  
while Return Air duct shall be used for Make-up Air in case of Fire.  
Motorized damper which is installed in Supply & Return Air duct shall be normally  
open and motorized damper installed in Smoke & make-up air duct shall be normally closed,  
while in case of Fire motorized damper which is installed in Supply & Return Air duct  
shall be closed and motorized damper installed in Smoke & make-up air duct shall be open.

