



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the genl

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.



0124-2322427

Fax
No.

0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

M/s Whiteland Corporation Pvt Ltd.,
10th & 11th floor, Tower 1, World Mark,
Sector-65, Gurugram.

Memo No. Ch- 44 / Drg.-PLC Dated: 22/02/2024

Sub:

Assurance Certificate of DHBVN for setting up of Mix Land use (98% GH and 2% Comml) under License No.263 of 2023 Dated 12.12.2023 by DTCP Haryana valid upto 11.12.2028 under TOD policy over an area measuring 9.58125 acres in revenue estate of village-Dhanwapur, Sector-103, Gurugram, being developed by M/s Whiteland Corporation Pvt. Ltd. Declared load 6616 KVA.

Ref:

Your firm letter No. Nil dated 09.02.2023 on the subject cited above.

It is hereby assured that the power requirement of tentative load of 6616 KVA shall be considered from the nearest 220/33KV sub-station at the time of actual requirement as per DHBVN norms at the voltage level of 33KV subject to the following conditions:-

1. Subject to availability of power and infrastructure at the time of actual release of connection.
2. Necessary charges will be got deposited by you as per latest Nigam instructions and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam/HERC Regulations.
3. The necessary infrastructure will be laid by you at your own cost. The piece of land will be provided by you for the switching station / sub-station as per instructions of the Nigam.
4. This letter will be valid till the validity of license in view of Sales Circular no. D-6/2022 issued by CE/Commercial, DHBVN, Hisar vide memo no. Ch-06/SE/C/R-16/380/Vol-I dated 10.03.2022.


Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The XEN'OP' City Divn. DHBVN, Gurugram for information, please.