DAKSHIN HARYANA BIJLI VITRAN NIGAM

LA Government of Huryana Undertaking)

Superintending Engineer 'OP' Circle Mehrauli Road, Gurugram.

0124-2322427

0124-2306590

e-mail se.gurgaon@gmail.com

To:

M/s Karma Lakelands Pvt. Ltd. 5, Green Avenue, Vasant Kunj, New Delhi-110070.

Memo No. Ch- 26

/ Drg.-PLC Dated:

12 /01/2024

Sub:

Revise Assurance Certificate of DHBVN for Residential Colony Project known as Karma Lakelands, village-Naurangpur, Sector-80, Gurugram Declared load 5367.29KW.

Reference your firm letter No. Nil dated 05.01.2024 on the subject cited

above.

In continuation to this office memo No.Ch-12/Drg.-PLC dated 13.12.2023 and power requirement of your project bearing (License No.-180 of 2023 Dated 05.09.2023 by DTCP Haryana valid upto 04.09.2028) land measuring 31.28125 acres, shall be considered from the nearest source 220/33KV S/Stn., Gurugram or any other source at the time of release your load at 33KV level or the voltage level of the applied load. The load requirement of this project would be evaluated as per DHVBN norms. However, this assurance is subject to the following conditions:-

- 1. Subject to availability of power and infrastructure at the time of actual release of connection.
- 2. Necessary charges will be got deposited by you as per latest Nigam instructions and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam/HERC Regulations.
- 3. The necessary infrastructure will be laid by you at your own cost. The piece of land will be provided by you for the switching station / sub-station as per instructions of the Nigam.
- 4. This letter will be valid till the validity of license in view of Sales Circular no. D-6/2022 issued by CE/Commercial, DHBVN, Hisar vide memo no. Ch-06/SE/C/R-16/380/Vol-l dated 10.03.2022.

Superintending Engineer OP' Circle-I DHBVN, Gurugram

Copy to:-

The XEN 'OP' Divn, DHBVN Manesar.