



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the general



0124-2322427



0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

M/s Krisumi Corporation Pvt. Ltd.
3rd floor Central Plaza Mall, Golf Course Road
Sector-53, Gurugram, Haryana-122002.

Memo No. Ch. 68 / Drg.-PLC

Dated: 27/03/2024

Sub:

Request for issuance of power assurance letter for the upcoming phase-3,4,7 & EWS project over an area measuring 30.38125 acres (License No. 39 of 2013, 85 of 2014 & 166 of 2023) being developed by M/s Krisumi Corporation Pvt. Ltd. in Sector-36A, Gurugram. Declared load 7009kW with CD-7788kVA.

Ref :

Your Firm letter No. Nil dated 26.03.2024.

It is hereby assured that the power requirement of tentative load 7009kW with CD-7788kVA shall be considered from the nearest 220/33kV sub-station at the time of actual requirement as per DHBVN norms at the voltage level of 33kV subject the following conditions:-

1. Subject to availability of power and infrastructure at the time of actual release of load.
2. Necessary charges will be got deposited by you as per latest Nigam instructions and compliance of all other instructions of Nigam will be ensured as per standing instructions of the Nigam/HERC regulation.
3. The necessary infrastructure will be laid by you at your own cost. The piece of land will be provided by you for the switching station/sub-station as per instructions of the Nigam.
4. The letter will be valid till the validity of license in view of sales circular No.D-6/2022 issued by CE/Commercial, DHBVN, Hisar vide Memo. No.Ch-06/SE/C/R-16/380/Vol-I dated 10.03.2022.

27/3/2024
Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' Divn. DHBVN, Manesar for information.