



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the Genl

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.

0124-2322427

Fax No. 0124-2306590

e-mail scop1gurugram@dhbvn.org.in



To

M/s JMS Infra Reality Pvt. Ltd
Plot No. 10, 3 rd Floor, Sector-44
Gurugram-122002, Haryana
Email:manish.kumar@jmsgroup.co.in

Memo No. Ch. 24 /Drg/PLC

Dated: 02/06/2023

Sub: Issuing assurance power supply of ultimate power load (2077 KVA) for setting up Affordable Plotted Colony under DDJAY on additional area measuring 3.34375 Acres. Additional area measuring 2.45625 acres in addition to license No. 11 of 2022 dated 02.02.2022 area 16.55625 acres totaling area 22.35625 acres at sector- 95, Waizirpur, Gurugram in the name of M/s JMS Infra Reality Pvt. Ltd.

Ref : 1. Your Firm Letter dated 30.05.2023 recived in this office on dated 2.6.2023.

It is conveyed that power requirement of your project bearing License No. 111 Of 2023 dated 25.05.2023 which is Valid upto 24.05.2028 shall be considered from the nearest source i.e (proposed) 220/33 KV S/Stn, Gurugram or any other source at the time of release of your load at 33 KV level or the level applied at the time of release of load. The load requirement of this project would be evaluated as per DHBVN norms. The assurance is subject the following conditions:-

1. Availability of power and infrastructure at the time of actual release of load.
2. Deposition of necessary charges by you as per instructions of the Nigam and compliance of all other instructions of Nigam as per standing instructions of the Nigam/HERC regulation.
3. The necessary external & internal infrastructure as per approved Electrification Plan will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer for getting of approval of building plan from DGTCP, Chandigarh, Haryana.
5. The validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to appling for revised assurance letter.

Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:

The Xen 'Op' Divn DHBVN, Manesar