

[illegible]

Downloaded from <http://ajphaphysocpharm.sagepub.com/> at 11:01 11 November 2014

QSR NO	SYMBOL
1.	
2.	
3.	
4.	
5.	
6.	
7.	
8.	
9.	
10.	

SR. NO.	SYMBOL	DESCRIPTION
1.		SMOKE DETECTOR
2.		MULTICRITERIA DETECTOR
3.		DETECTOR FOR SHAFTS
4.		SPEAKER
5.		MANUAL CALL POINT
6.		MONITOR MODULE
7.		HOOTER
8.		FIRE ALARM PANEL
9.		CONTROL MODULE
10.		TALK BACK

NOTES:

1. ALL DIMENSIONS ARE IN MM.
2. GATE AND BOUNDARY WALL SHALL BE AS PER STANDARD DESIGN.
3. SPRINKLERS WILL BE PROVIDED IN ENTIRE BUILDING INCLUDING BASEMENTS AS PER N.B.C.
4. HOT WATER HEATING SYSTEM WILL BE PROVIDED AS PER N.B.C.
5. 100% POWER BACK UP WILL BE PROVIDED FOR LIFTS & ESSENTIAL SERVICE AREAS.
6. DISABLED RAMP @ 1:12 SLOPE WITH 900MM HIGH RAILING.
7. ALL BUILDINGS ARE MECHANICALLY VENTILATED.
8. SLODES FOR EARTHQUAKE RESISTANCE AS PER RELEVANT IS CODES.
9. THE TRAVEL DISTANCE NOT MORE THAN 45 METER

PROPOSED BUILDING PLAN OF
COMMERCIAL COLONY AREA
MEASURING 3.99 ACRES (LICENCE NO.
119 DATED 05-06-2023) FALLING IN
SECTOR -70, GURUGRAM BEING
DEVELOPED BY NORTH STAR TOWERS
PVT. LTD., (MATRIX BUILDWELL PVT. LTD.,
IN COLLABORATION WITH NORTH STAR
APARTMENTS PVT. LTD. (NOW KNOWN
AS SS GROUP PVT. LTD.)

UDAYAN CHAUDHARI & ASSOCIATES PVT. LTD.
40/60, GROUND FLOOR, C.R.PARK,
NEW DELHI-110019
E-mail : udayanchaudhari@gmail.com
Website : www.udayanchaudhari.com

ACPL Design Ltd

Certified that fire Fighting Scheme is
as per N.B.O. Part-V

NEW DELHI 110048 INDIA

16

DRAWN -	CHECKED -	SCHEMATIC Gungahman Northey Gungahman	NORTH Gungahman
PP	RP	The Fighting Scheme Approved DRAFTWORK ONLY	12.12.2023
DRAWING TITLE -			Deputy Director (R) ELFV/FAPA-08
THIRD FLOOR PAS & PA SYSTEM LAYOUT			

For SS Group Pvt. Ltd.
Authorised Signatory
OWNER'S SIGNATURE

10/20/93