






DOOR WINDOW SCHEDULE (TOWER-1) (ABOVE 1ST FLOOR LVL.)

S.NO.	TYPE	WIDTH	CILL	LINTEL	DESCRIPTION NO.
1	D1	1200	-	2400	ENTRANCE (ONE HOUR FIRE RATED)
2	D2	1000	-	2400	BED ROOM
3	D3	1000	-	2400	KITCHEN
4	D4	750	-	2400	TOILET/STORE
5	D4a	800	-	2400	UTILITY
1	DW1	1350	150	2400	KITCHEN
2	DW2	1975	150	2400	BEDROOM-1
3	DW3	2450	150	2400	M.BEDROOM
4	DW4	3000	150	2400	LIVING/DINING
5	DW5	2330+2550	150	2400	LIVING/DINING
6	DW6	2875	150	2400	MASTER BEDROOM
7	DW7	2400	150	2400	BEDROOM-1
8	DW8	1275	150	2400	BED-2
9	DW9	1275	150	2400	DOMESTIC SERVANT
1	W1	900	900	2400	BEDROOM-1
2	W2	1200	900	2400	BEDROOM-1
3	W3	1500	900	2400	BEDROOM-2
4	W4	1650	900	2400	MASTER BEDROOM
5	W5	1800	900	2400	BEDROOM-1
1	V1	450	1200	2150	U.TOILET
2	V2	600	1200	2150	TOILET
3	AP	750	600	1800	TOILET
1	FD1	1200	-	2400	STAIRCASE(2HOUR FIRE RATING)
2	FD2	1500	-	2400	STAIRCASE(2HOUR FIRE RATING)
3	FD3	1200	-	2400	ELECTRICAL SHAFT(2HOUR FIRE RATING)
4	FD4	600	-	2400	LV SHAFT(2HOUR FIRE RATING)
5	AS				ARCHITECTURAL SCREENS



Fire Fighting Scheme Approval
Vide letter No. SF/2019/18
Date: 07/02/19
ADFC/19

	FIRE HOSE CABINET
	FUTURE CONNECTION
	UPRIGHT TYPE SPRINKLER
	PENDENT TYPE SPRINKLER
	SIDE WALL SPRINKLER
	9 Ltr. WATER GAS PRESSURE TYPE FIRE EXTINGUISHER
	4.5 kg CO2 TYPE FIRE EXTINGUISHER
	BUTTER FLY VALVE
	FLOW INDICATING SWITCH

NOTE -
EACH FIRE HOSE CABINET SHALL CONSIST OF
1 No. - S.S. SINGLE HEADED HYDRANT
2 Nos. - FIRE HOSES 63mm 15M LONG WITH ACCESSORIES.
1 No. - SHORT BRANCH
1 No - FIRST AID HOSE REEL
2 Nos - FIRE EXTINGUISHERS
1 No - FIRE MAN'S AXE.

NOTE:

CERTIFIED THAT THESE DRAWINGS ARE AS PER ORIGINAL APPROVED DRAWINGS WIDE TOWN PLANNING / HUDA LETTER MEMO NO. - ZP-1223/SD/BS/2018/24604 DATED - 14.09.18

DESIGN ARCHITECT :-

RKA
RAJINDER KUMAR ASSOCIATES
ARCHITECTS
PLANNERS
DESIGNERS
ENGINEERS
B-477 SHOPPING CENTRE
SAFARHALL ENCLAVE
NEW DELHI - 110029
INDIA
T: 91 11 26160200-31
F: 91 11 26160274

MEP CONSULTANT:-

V
B-50, Basement, Soami Nagar
New Delhi-110017
Tel No. 011-49848197 & 49849205
Consulting Email: info@vconsulting.co.in

STRUCTURAL ENGINEER :

EDR
738/ S-2)Second Floor
Niti Khand - 1,
Indrapuram Ghaziabad, U.P, India.
Cell: +91-9971122470
Email: santosh.singh@edr-group.com
Web: www.edr-group.com

CLIENT NAME :

SH. RAVIJEET SINGH & SH. PAWAN KUMAR IN COLLABORATION WITH ALPHA CORP DEVELOPMENT PVT. LTD.

PROJECT TITLE

PROPOSED BUILDING PLAN OF GROUP HOUSING COLONY FOR AN AREA MEASURING 2.364063 ACRES (LICENSE NO. 13 OF 2018 DATED 09.02.2018) BEING DEVELOPED BY SH. RAVIJEET SINGH & SH. PAWAN KUMAR IN COLLABORATION WITH ALPHA CORP DEVELOPMENT PVT. LTD. IN THE REVENUE ESTATE OF VILLAGE GURUGRAM, SECTOR-15, PART-II, GURUGRAM, MANESAR URBAN COMPLEX, TEHSIL & DISTRICT GURUGRAM, HARYANA.

CLIENT'S SIGNATURE & STAMP

Signature
Gill View Corporate Towers Sector-42
Gurgaon - 122001

ARCHITECT'S SIGNATURE & SEAL :

Signature
RAJINDER KUMAR
CA/2490/75

STAMP

Stamp of the Fire Fighting Scheme is 25 years valid from the date of issue.

Signature
F50 Gurugram
Signature
F50 Gurugram
Signature
F50 Gurugram

DRAWING STATUS

SUBMISSION DRAWING

DRAWING TITLE

POCKET-1
18TH & 27TH FLOOR PLAN AND

LEGEND:-

SYMBOL	DESCRIPTION
	BELOW FALSE CEILING DETECTOR
	ABOVE FALSE CEILING DETECTOR
	HEAT DETECTOR
	SMOKE DETECTOR
	RESPONSE INDICATOR
	MANUAL CALL POINT
	TELEPHONE JACK
	HOOTER
	EXIT SIGN
	FIRE PANEL

V Consulting
Fire Consultant
(Fire Fighting, Electrical & Ventilation)
B-50, Basement
Soami Nagar, New Delhi