

DAKSHIN HARYANA BIJLI VITRAN NIGAM

0124-2322427



Office of the gmol Superintending Engineer 'OP' Circle-I Mehrauli Road, Gurugram.

(A Government of Haryana Undertaking)

0124-2306590 No

seop1gurugram@dhbvn.org.in e-mail

Fax

То

M/s Ojos Developers Pvt. Ltd. 411, 4th Ambadeep Building 14 K.G Marg Connaught Place New Delhi-110001. e-mail-info@ojos.net.in

Memo No. Ch.) & / Drg.-PLC

Dated: 24/06/2024

- Sub: Request for assuring load of 1678kW in respect of our upcoming plotted Commercial Project at Sector-114, village-Bajghera Gurugram bearing Licence No.65 of 2024 dated 18.06.2024 land measuring 5.1375 acres developed by Ojos Developers Pvt. Ltd.
- Ref: Your firm Letter No. dated 19.06.2024 recived in this office on dated 24.06.2024.

It is hereby assured that the power requirement of tentative load of 1678KVA for shall be considered from the nearest 220/33kV sub-station at the time of actual requirement as per DHBVN norms at the voltage level of 33kV subject to the following conditions:-

- 1. Subject to availability of power and infrastructure at the time of actual release of connection.
- 2. Necessary charges will be got deposited by you as per latest Nigam instructions and compliance of all other instructions of Nigam will be ensured as per standing instructions of the Nigam/HERC regulations.
- 3. The necessary infrastructure will be laid by you at your own cost. The piece of land will be provided by you for the switching station/sub-station as per instructions of the Nigam.
- 4. This letter will be valid till the vailidity of license in view of sales Circular No.D-06/2022 issued by CE/Comml. DHBVN, Hisar vide Memo. No.06/SE/C/R16/380/Vol-1 dated 10.03.2022.

Superintending Engineer OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' City Divn. DHBVN for information.