

Checked and found ok for Public Health
(Internal) Services only subject to comments in
in forwarding letter No. 21533 dated 08/12/2023

Superintending Engineer (HQ)
for Chief Engineer-I
HSVP, Panchkula

SANCTIONED
TO BE READ WITH THIS OFFICE
MEMO NO. 148-C1
DATED: 08/02/2023

DTP (HQ) S.T.P (HQ) S.T.P (G) C.T.P (HQ)
Member Chairman
B.P.A.C. B.P.A.C. B.P.A.C.
Consultant Architect
Note:- DTP (HQ) (Dinesh Kumar PAUHQ)

1. BUILDING HAS AUTOMATIC SPRINKLER SYSTEM WHEREVER REQUIRED BY NBC.
2. BUILDING WILL BE DESIGNED (STRUCTURES) AS PER RELEVANT IS CODES FOR EARTH QUAKE RESISTANCE.
3. ALL DIMENSIONS ARE IN METERS

FIFTH FLOOR- AREA DIAGRAM ADDITIONS

SCALE - 1:300

