

1. BUILDING HAS AUTOMATIC SPRINKLER SYSTEM
WHEREVER REQUIRED BY NBC.

3. ALL DIMENSIONS ARE IN METERS

DOOR/WINDOW SCHEDULE			
TYPE (IN MM)	WIDTH (IN MM)	CILL (FROM FL)(IN MM)	INTEL (FROM FL)(IN MM)
GLAZING			
G1	AS/ELEVATION		
DOORS			
FD1	2250	0	2450
FD2	1500	0	2450
FD3	1500	0	2450
FHC	900	150	2450
D1	1200	0	2450
D2	2150	0	2450
D3	1800	0	2450

"PROPOSED BUILDING PLANS OF COMMERCIAL COLONY MEASURING 3.6562 ACRES (LICENSE NO. 60 OF 2013 DATED 16.07.2013) AND 3.9937 ACRES (LICENSE NO. 61 OF 2013 DATED 16.07.2013) TOTAL AREA MEASURING 7.6499 ACRES IN SECTOR - 82, GURUGRAM MANESAR URBAN COMPLEX BEING DEVELOPED BY ELAN IMPERIAL PRIVATE LIMITED (FORMERLY KNOWN AS AMBIENCE INFRASTRUCTURE DEVELOPERS PVT. LTD.)"

S.N.O.	SYMBOL	TAG	DESCRIPTION:
(1)		110 OD SOIL PIPE	
(2)		110 OD WASTE PIPE	
(3)		150 OD WASTE PIPE FOR KITCHEN	
(4)		75 OD ANTISIPHONAGE PIPE	
(5)		DOMESTIC WATER SUPPLY PIPE	
(6)		FLUSHING WATER SUPPLY PIPE	
(7)		150 OD RAIN WATER PIPE FOR TERRACE	
(8)		110 OD RAIN WATER PIPE FOR BALCONY	
(9)		DOMESTIC WATER RISER PIPE	
(10)		SOFT WATER RISER PIPE	
(11)		FIRE HYDRANT PIPE	
(12)		FIRE DRAIN PIPE	
(13)		FIRE SPRINKLER PIPE	
(14)		FD FLOOR DRAIN	
(15)		FT FLOOR TRAP	
(16)		UT URINAL TRAP	
(17)		COP CLEAN OUT PLUG	

For Elan Imperial Private Limited

 Authorised Signatory

RAJINDER KUMAR
GA/2490/75

SECOND FLOOR PLAN &
SECOND FLOOR AREA DIAGRAM

Population Calculation 2ND FLOOR	AREA	POPULATION
TOTAL POPULATION RETAIL (@6 SQ.M. PP)	13204.373	2201

Staircase width calculation						
Floor	Population	per unit width (mm)	Total width required (mm)	Total exit width provided		
				Staircase width (mm)	No. of staircase	Total exit width (mm)
2nd Floor	2201	10	22007	2250	9	20250
				2000	1	2000
				2500	1	2500
				11	24250	

2ND FLOOR (RETAIL)									
POPULATION		PERMANENT POPULATION (10%)		FLOATING POPULATION (90%)		TOTAL REQUIRED		TOTAL PROVIDED	
		220		1981					
2201		MALE(2/3)	FEMALE (1/3)	MALE(2/3)	FEMALE (1/3)	MALE	FEMALE	MALE	FEMALE
		147	73	1320	660				
	W.C.	6	5	27	14	33	19	33	19
	URINAL	6	0	27	0	33	0	33	0
	W.B.	6	5	27	14	33	19	33	19

SECOND FLOOR PLAN

Checked and found ok for F. Nic Health
(Internal) Service only subject to comments in
in forwarding letter No 27/537 20/12/2022

Superintending Engineer (H
for Chief Engineer-I
HSVP, Panchkula