



## **HARYANA VIDYUT PRASARAN NIGAM**

Regd. Office: Shakti Bhawan, Plot No. C-4, Sector-6, Panchkula, 134109.

Corporate Identity Number: U40101HR1997SGC033683

Website: www.hvpn.org.in, E-mail -xentsmns@hvpn.org.in

Telephone No. -0124-2981283, 09313472678

### **TO WHOMSOEVER IT MAY CONCERN**

(Completion/Handing over certificate)

Memo no. **ch-348/S-9**

Dated: - **10.07.2024**

This is to certify that the shifting/re-alignment of 66kV D/C Dalutabad-Harsaru line between TL No. 20 to 22 infringing the land of M/s Skywhales Developers LLP in Sector-99 Gurugram from overhead to underground XLPE 1200 Sqmm cable as a deposit work of M/s Skywhales Developers LLP under self-execution scheme as approved by WTD's of the Nigam vide e-office file. No. HVPNL-TLMN03879/2/2023-TL CONST SDIV MANESAR (Computer no. 977246) under self-execution scheme has been successfully completed by M/s Skywhales Developers LLP through their approved vendor i.e. M/s JMD Electricals, 1<sup>st</sup> floor, Flat no. A249, Today Blossom-I, Sector-47, Gurugram on dated 16.12.2023 and accordingly taken over by HVPNL.

However, the above certificate does not relieve M/s Skywhales Developers LLP from any financial obligations/shortcoming on part of M/s Skywhales Developers LLP for execution of above shifting/re-alignment work including asset transfer charges etc. and any other associated cost that may arise in future which is to be paid by M/s Skywhales Developers LLP to HVPNL.

**SDO Construction S/Div.  
HVPNL Manesar**

**Executive Engineer,  
TS Division, HVPNL,  
Sec-1, IMT Manesar**

**Office of the  
Executive Engineer, Electrical Inspectorate, Haryana,  
526/19, Shivaji Nagar, Opp. S.D Public School (Khandsa Road),  
Gurugram (e-mail: [xenceiggn@gmail.com](mailto:xenceiggn@gmail.com)).**

---

To

Executive Engineer  
TS Divn. HVPNL  
Sector-1, IMT Manesar.

Application No. 1938-0591

Dated:- 13/12/2023

Memo No:

18494

Dated: 16/12/2023


Subject: Inspection of 66 KV Daultabad-Harsaru Line (D/C) with two nos. newly erected mono-poles between TL no. 20 to 22 with U/G XLPE Cable, infringing the land of M/s Skywhales Developers LLP, Sector-99-A, Gurugram.

Reference your office memo no. Ch.Spl-1 dated 14/12/23 on the subject noted.

The subject cited installation was inspected by this department on 16-12-2023 and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. The approval to energise the same is hereby accorded. However the following observations were found which needs to be attended before energisation:-

1. Fencing be provided around both the newly erected mono-poles.
2. Spare cable be secured properly at both mono-poles.

Consistent compliance of the relevant provisions of CEA Regulations, 2010 be ensured in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

  
Assistant Engineer  
Electrical Inspectorate, Haryana,  
1st Floor, 526/19, Shivaji Nagar,  
Opp. S.D Public School, Gurugram-1