

To

MD. IREO CORRIDOR-67.

M/s Precision Realtors Pvt. Ltd.  
C/o IREO Grace Realtech Pvt. Ltd.  
At IREO Grace Group Housing  
Sector-67A, Gurgaon-Manesar Urban Complex,  
Gurugram.

Memo No:

D/59/CH-2

Dated:

25/6/2018

Subject:


Approval of drawing of M/s Precision Realtors Pvt. Ltd. C/o IREO Grace Realtech Pvt. Ltd.,  
At IREO Group Housing, Sector-67A, Gurgaon-Manesar Urban Complex, Gurugram.

Reference your letter no. Nil dated 04.06.2018 on the subject noted above.

The single line diagram for installation comprising of 2x7500 KVA 33/11KV, 10x1600 KVA 11/0.415KV, 2x630 KVA 11/0.415KV T/Fs & 4x2000 KVA, 4x1500 KVA D.G sets of the subject cited applicant is hereby approved subject to the following:-

1. Relevant provisions of "Central Electricity Authority (Measure relating to Safety and Electric Supply) Regulations, 2010" will be complied with.
2. The generation/transmission/distribution/trading/consumption/captive use of electricity will be made after necessary approval of competent Authority prescribed in the Electricity Act 2003 and the Electricity Rules 2005. A copy of relevant approval be furnished white offering inspection of the installation.
3. Various electrical equivalents will be placed / installed as per National building code and others prevalent practice.
4. All LV /MV panels will be placed inside enclosure at a safe place.
5. The energy meters will be installed at the main gate of the premises.
6. Neutral point and body of transformers be provided two separate and distinct earths with copper/GI strip as per IS :3043-1987.
7. The 33/11 KV VCB will have breaking capacity of 26/18.4KA.
8. The distance between building and sub station should be maintained as per norms.

DA/Approved Drawing.

  
Chief Electrical Inspector  
to Govt., Haryana, Chandigarh

CC:

The Executive Engineer, Electrical Inspectorate, Haryana, Gurugram for information.