

25/10/17  
12.23 PM

96

EP & SOL:2017\*322\*

DHBVN

DAKSHIN HARYANA BIJLI VITRAN NIGAM  
(A Power Distribution & Retail Supply Utility, Govt. of Haryana)  
An ISO 9001:2008 Complaint Utility, CIN: U99999HR-1999SG034165  
Chief Engineer/Commercial, DHBVN, Hisar.  
Regd. Office Vidyut Sadan, Vidyut Nagar, Hisar-125005 (Haryana)  
Phone No. 01662-223093 Fax: 01662223153  
Website: dhbvn.org.in E-mail: cecommercialdhbvn1@gmail.com

DHBVN

To,

SE/OP, Circle,  
DHBVN, Gurugram-II

Subject:- Memo No: - Ch- 6 /SE/C /SOL-46/ Dated: - 25/10/2017  
Approval for electrification scheme with ultimate load of 2677 KW /2974 KVA as well as sanction of partial load of 2400KW /2667 KVA to M/s IREO (P) Ltd. Sector-59, Gurugram applied vide A&A no. 40157/HT/NDS dated 17.7.17 under SDO/Op S/Divn DHBVN, Badshahpur, Gurugram.

Please refer to SDO/Op S/Divn DHBVN, Badshahpur, Gurugram office Memo No. 579 dated 28.7.17 vide which a case file has been sent for approval for electrification scheme with ultimate load of 2677 KW /2974 KVA as well as sanction of partial load of 2400KW /2667 KVA to M/s IREO (P) Ltd. Sector-59 , Gurugram applied vide A&A no. 40157/HT/NDS dated 17.7.17 .

Approval for electrification scheme with ultimate load of 2677 KW /2974 KVA as well as sanction of partial load of 2400KW /2667 KVA to M/s IREO (P) Ltd. Sector-59 , Gurugram applied vide A&A no. 40157/HT/NDS dated 17.7.17 under HT/NDS category under single point, is hereby accorded subject to compliance of the terms and conditions given as under:-

CHD  
to write to  
A&A scheme  
&  
to B/Pur  
to submit  
compliance of all  
points  
particularly pt no 2  
before  
release of conn.

1. The developer shall install dry type distribution transformers 33/0.4 KV of rating 3X2000 KVA (total capacity 6000KVA) to cater their ultimate load by considering maximum loading of 80% of the rating of each distribution T/F. From safety aspect, an NOC in this regard may be obtained from Chief Electrical Inspector, besides ensuring compliance of all safety measures by SE/Op, Gurugram-II.
2. Ultimate load of 2677 KW /2974 KVA as well as partial load of 2400KW /2667 KVA to M/s IREO (P) Ltd. Sector-59 , Gurugram applied vide A&A no. 40157/HT/NDS dated 17.7.17 shall be released after energization of 220/33 KV S/Stn, Sec-57 Gurugram through proposed 33 KV Switching station to be erected through 33 KV independent feeder with double run, 3C x 300 mm2 U/G XLPE cable at the cost of applicant.
3. Guidelines given in Sales Instruction No. 21/2015 shall be complied with by the applicant.
4. Complaint centers shall be constructed by the applicant as per Nigam instructions No. P&D 9/2011.

25/10

5. An undertaking be obtained from the consumer that the technical feasibility shall be examined afresh every time the consumer applies for extension of load.
6. The applicant either deposit ACD corresponding to ultimate load in cash in one go or ACD corresponding to partial load in cash and ACD for balance of ultimate load in the shape of BG.
7. SE/OP, DHBVN Gūrugram-II should personally ensure that the BG of independent feeder and electrical infrastructure is deposited by the applicant as per Nigam instructions and commensurate with the ultimate load, prior to release of load including partial load.
8. CEA guidelines and IE rules regarding Safety precaution should be adhered to for connecting the electrical system.
9. The applicant will enter into tripartite agreement with HVPN and DHBVN, if required.
10. Share cost if required, be deposited as per Nigam instructions from the applicant.
11. No applicant, senior to the instant applicant/ consumer is waiting for sanction of load / extension of load.
12. Processing charges, Consumption security & other applicable charges be recovered from the applicant as per Nigam Instruction.
13. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card, driving license etc. shall be obtained from the applicant / consumer.
14. The applicant will submit documentary proof in support of ownership of land.
15. Non- judicial stamp worth Rs. 3/- on the left corner of A&A be got affixed by the SDO before taking further action.
16. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.
17. The applicant shall comply with the instructions of the Nigam issued by this office time to time.
18. The HT brochure may contain old instructions, as such an additional affidavit be obtained from the consumer to abide by the provision of the Electricity Act 2003 and complying of all the instructions of SMI & Sales Circular issued as well as amended by the Nigam from time to time before release.
19. Necessary clearance from various Govt. Department i.e. CEI, Pollution Control Board etc. shall be taken.

20. Protection scheme to be provided on independent feeder at the applicant's end for obtaining supply at 33KV level be got approved from the M&P wing of both DHBVN & HVPN.
21. The tariff to be charged from the occupants should in accordance with tariff schedule approved by HERC.
22. For the creation of S/Stn. / transmission lines & before erection of major items, inspection will be got carried out from DHBVN / HVPN Authorities. The inspection charges @ 1.5% of the estimated cost of work shall be paid by the applicant to DHBVN / HVPN as the case may be.
23. The applicant shall erect underground HT lines & other infrastructure as per specification and design of the Nigam.
24. All other formalities as required as per instruction issued/adopted by Nigam time to time shall be completed.
25. Metering equipments including CTs of matching capacity as per specifications / design of Nigam shall be provided at feeding S/Stn. as per Nigam instructions.
26. The applicant shall comply with the provision of Haryana Renewable Energy Department regarding installation of solar photovoltaic Power Plant applicable time to time.

This issues with the approval of Director/Projects, DHBVN, Hisar at NP- 4 of file No.SOL-461

*The*  
CE/Commercial  
DHBVN, Hisar

CC to:-

1. PS to Director/*Project* DHBVN, Hisar for kind information of Director/ please.
2. CE/PD&C, DHBVN, Hisar.
3. CE/Op, DHBVN, Delhi.
4. CE/Planning, HVPN, Panchkula
5. CE/TS, HVPN, Hisar.
6. SE/TS, HVPN, Gurugram
7. SE/NCR, HVPN, Gurgaon.
8. XEN (OP), Division, DHBVN, Sohna.
9. SDO 'OP' S/Divn., DHBVN, Badshahpur.
10. M/s IREO (P) Ltd. Sector-59, Gurugram

*Enclt Noch-96 / DGR-7 dt 26-10-2017*  
*Copy of the above is forwarded to XEN OP*  
*Divn. DHBVN Sohna for information*  
*and f. N. action please*

*(SE. OP. circled)*