



Office of the
Chief Electrical Inspector to Govt, Haryana
SCO 117-118, Sector-17-B, Chandigarh (e-mail: cei_goh@yahoo.com)
Telephone No. 0172-2704090, Fax No. 0172-2710171
Website: - www.ceiharyana.in

To

M/s Silverglades Homes LLP
Project at: NIPL Vill. Behrampur
Sector 63 A, Gurugram

Memo No: 5/631

Dated: 02.01.24

Subject: Approval for Single Line Diagram M/s Silverglades Homes LLP
Project at: NIPL Vill. Behrampur Sector 63 A, Gurugram

Reference your office letter no. nil dated nil on the subject noted above. The single line diagram for installation comprising of 4x2000 KVA T/Fs & 4x2000 KVA, 2x750 KVA DG Sets of the subject cited applicant is hereby approved subject to the following: -

1. Relevant provisions of "Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2023" will be complied with.,
2. The generation/transmission/distribution/trading/consumption/captive use of electricity will be made after necessary approval of competent Authority prescribed in the Electricity Act 2003 and the Electricity Rules 2005. A copy of relevant approval be furnished while offering inspection of the installations.
3. Various Electrical equipment will be placed / installed as per National Building Code and others prevalent practices.
4. All LV/MV panels will be placed inside enclosures at safe place.
5. The energy meter will be installed at the main gate of the premises.
6. Neutral point and body of transformers be provided two separate and distinct earths with copper/GI strip as per IS: 3043-1987.
7. The switchgears will have breaking capacity commensurate with the specifications of Power Utility.
8. The distance between building and substation should be maintained as per norms.
9. Smart Energy Meter be installed at each generating units as per DHBVN/ UHBVN specifications for recording of power.
10. Proper Electrical and Mechanical Interlocking system be provided between breakers.
11. All electrical work should be carried out through licensee electrical contractor.
12. Ensure that all electrical equipment including transformers comply with latest IS Standards.
13. Strict Compliance of section 4.3.1 of National Building Code 2016 Volume-II & Regulation 44 of "Central Electricity Authority" (Measures relating to safety and Electric supply) Regulation, 2023"

DA/ Approved Drawing


Chief Electrical Inspector
to Govt., Haryana, Chandigarh