


TOTAL COVERED AREA DETAILS					
S.NO.	FLOOR'S	NON F.A.R	F.A.R	TOTAL	
1	BASEMENT	1707.05	0.00	1707.05	
2	GROUND FLOOR	0.00	1436.95	1436.95	
3	FIRST FLOOR	392.36	1101.23	1493.59	
4	SECOND FLOOR	66.21	808.91	875.12	
5	TERRACE	87.65	0.00	87.65	
	SUB TOTAL	2253.27	3347.09	5600.364	
TOTAL CONSTRUCTION AREA=			5600.36	SQ.M.	

DRG. NO.-2441/ F-01

PROJECT:

PROPOSED COMMERCIAL POCKET AREA MEASURING 2499.65 SQM (0.61 ACRE) FORMING PART OF AFFORDABLE RESIDENTIAL PLOTTED COLONY UNDER DEEN DAYAL JAN AWAS YOJNA OF LIC.NO 33 OF 2023 DATED 16.02.2023 AREA 4.30625 ACRE ADDITION IN LICENSE NO. 108 OF 2022 2021 1116 DATED 05.08.2022 AREA 11.39375 ACRE, TOTAL AREA 15/70-1-24 ACRE IN SECTOR-93 GURUGRAM UNDER THE MASTER DINCO (Tech)
PLAN OF GURGAONMANESAR URBAN COMPLEX 2031.



IT IS CERTIFIED THAT DRAWINGS ARE AS PER ORIGINAL DRAWING APPROVED BY CHAIRMAN BUILDING PLAN APPROVAL COMMITTEE, FOR LICENESED COLONIES/ CONTROLLED AREA GURGAON,

MEMO NO.- 7514 DATED.- 23-11-2023



ARCHITECT'S SIGN

OWNER'S SIGNATURE m burkers

OWNER'S SIGN

ARCHITECT'S SIGNATURE



FIRE CONSULTANT'S SIGNATURE





FIRE PROTECTION CONSULTANT RAMKUNWAR AND ASSOCIATES CONSULTING ENGINEERING SERVICES 100, G.F. INDIRA COLONY-1 SECTOR-52, GURUGRAM.

MOB. 09899004192 DRG. TITLE FIRE SUBMISSION

SITE PLANS

DRG. NO. DATE 2441/F-01 DEC./2023 SCALE 1:125 SIZE DRAWN BY:-A1 SHIVANI





From Director General

Fire Service, Haryana Panchkula

To M/s Sh Maninder Singh and Sh Prem Singh

Sector 93 Gurugram

Memo No. FS/2024/116 dated: 22/01/2024

Subject: Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group F-Mercantile Building at residential plotted colony in Sector 93, Gurugram meas. 2499.65 Sq. mtrs. of Sh.

Maninder Singh & Sh. Prem Singh:

Reference your Transaction Id 050262423000056 dated: 10/01/2024 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Gurgaon Sector-29, .The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions:-

Tower Name	Floor Detail	Terrace Height of Last Livable Floor(In Meters)	Ground Coverage	
01	G to 02	14.40 Mt.	1436.65 Sq. Mt.	
Tower Name	Basement Level	Basement Area	Basement Remarks	
	Basement- 01	1707.05 Sq. Mt.	-	

- The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) The above Fire Fighting Scheme is valid for Two Year from the date of issue of this letter.
- 9) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building

Remarks:- OK



Deputy Director (Technical)-I, for Director General, Fire Service, Haryana

Panchkula

Exercising the power of Director, Fire Services, Haryana