



From

Chief Engineer/ Comm.
UHBVN, Panchkula.

To

The SE 'OP' Circle,
UHBVN, Jhajjar.Memo No. Ch-07/SS-403/641/Lay.P/METL/CE/C-1
Dated: 25.04.2017

Subject:-

Memorandum of revised electrification layout plan for industrial colony area vide License No. 19 of 2011, 6 of 2012, 7 of 2012 and 8 of 2016 being developed by M/s Model Economic Township Ltd. (METL) (formerly Reliance Haryana SEZ Ltd.).

Please refer to your office memo no. Ch- 78/CC-136 dated 13.03.2017 vide which memorandum of revised electrification layout plan for industrial colony area vide License No. 19 of 2011, 6 of 2012, 7 of 2012 and 8 of 2016 being developed by M/s Model Economic Township Ltd. (METL) (formerly Reliance Haryana SEZ Ltd.) for setting up of Industrial Township was sent for approval.

As recommended by your office vide memo referred above, the proposal for electrical Layout plan of M/s Model Economic Township Ltd. (METL), Jhajjar having 365 acres land for which necessary license has been given by Director, Town & Country Planning Department, Haryana has been considered in view of the technical feasibility committee report held on dated 29.03.2017 and approved by the WTDs in circulation on 22.04.2017 for a load of 88.07 MVA on 220 KV level to be fed from at 220 KV Badana and 400 KV Sub-station Farukh Nagar through 220 KV double circuit line as deposit work. The firm will also deposit the cost of 2 nos. 220 KV bays to terminate 220 KV D/C line at both the feeding end sub-stations alongwith requisite charges as per instructions. The site of 220 KV Sub-Station shall be located at the load centre on left side of Jhajjar - Gurugram Road.

Also, the approval of electrification plan is subject to fulfillment of all terms and conditions of S.C. No. U-15/2015, U-31/2016, U-33/2016 & 35/2016 along with the following:-

1. The developer will erect and install 33/11 KV Sub-Stations and lines as per the load. Further, will install distribution transformers as per 80% loading condition of standard quality as per Nigam specification to cater the total load requirement of Township.
2. Inspection charges as per HERC norms be got deposited from the developer, if the work executed under Self Execution Scheme.
3. The Developer / Colonizer shall deposit the cost of bays and other charges with HVPN / UHBVN as per the Instructions of respective Nigam.
4. The developer / colonizer must install/erect whole Electrical Infrastructure as per Nigam's design, drawing & specifications within a period of five years after approval of electrification and hand over the system to the Nigam/RWA as applicable.

For Model Economic Township Limited

Authorized Signatory

Date of Receipt

XEN

H.C.

D. Accd.

D.H.D.

STERO

Date of Receipt

79/11/15

5. These load norms will be revised / updated every three years in sync with updation of EDC charges and will be made applicable prospectively.
6. The interim load of 4-5 MVA shall only be provided to the developer/colonizer subject to the following:-
 - a. Depositing of BG of the balance electrical infrastructure work to be completed as per S.C. No. U-35/2016.
 - b. Technical feasibility at the nearby Sub-Station.
 - c. The cost of the independent feeder shall be borne by the firm and after completion of the electrical infrastructure, it will be UHBVN property.
 - d. All other charges i.e. processing charges, ACD and service connection charges if any shall also be deposited.
7. SE 'OP' shall get the genuineness of the Bank Guarantee verified from the concerned bank branch.
8. Individual connections will be provided.
9. UHBVN reserves the right to recover the amount of inadequacy if any, arising later on.
10. The Firm shall bear the inspection fee of the Chief Electrical Inspector to Govt. of Haryana for inspection of system.
11. There should be double earthing arrangement of each equipment.
12. The quality of material to be used for Township shall be checked & approved by authorized person of UHBVN/HVPN as per instructions.
13. The Nigam officer shall personally ensure compliance of all above Technical & commercial points before releasing the connections.
14. The developer will abide by all the rules and regulations as amended from time to time.

DA/Files and MoM

Superintending Engineer /Comm
for Chief Engineer/Comm.
UHBVN, Panchkula

For Model Economic Township Limited

Authorized Signatory

1. PS to CMD for kind information of Worthy CMD, UHBVN, Panchkula.
2. SFS to Dir (T-I & T-II) for kind information of Directors, UHBVN, Panchkula.
3. CE (OP) UHBVN, Rohtak.
4. CE/PD&C, UHBVN, Panchkula.
5. CE/Plg, HVPN, Panchkula.
6. CE/TS, HVPN, Panchkula.
7. SFS to Dir (T-I & T-II) for kind information of Directors, UHBVN, Panchkula.
8. Company Secretary, UHBVN, Panchkula.

Endst No 953

dt. 22/5/17

The Copy of is forwarded
to Model Economic
Township Ltd. in village
Dadni Toe Shajjar for
further necessary action, timely
Compliance.

Endst No. 85/CC-136 Dt. 1-5-17
Copy of the above is forwarded to the
Xen (OP) Divn. Shajjar and this
Circle for further necessary action.

Sd/- (OP)
S/o S/Divn Shajjar

111

Subject:- Minutes of meeting dated 29.03.2017 in case of approval of revised electrification layout plan for industrial colony area vide License No. 19 of 2011, 6 of 2012, 7 of 2012 and 8 of 2016 being developed by M/s Model Economic Township Ltd. (METL) (formerly Reliance Haryana SEZ Ltd.) at Jhajjar.

The following were present:-

1. Sh. Naresh Sardana - Director (T-I), UHBVN, Panchkula.
2. Sh. S.K. Chhillar - Director (T-II), UHBVN, Panchkula.
3. Sh. Raj Pal - CE (OP) UHBVN, Rohtak.
4. Sh. M.S. Dahiya- CE/Comml., UHBVN, Panchkula.
5. Sh. Rakesh Jolly- CE/Planning, HVPNL, Panchkula.
6. Sh. R.K. Sharma - CE/PD&C, UHBVN, Panchkula.
7. Sh. Kulbir Singh - CE/TS, HVPNL, Panchkula.
8. Sh. A.K. Singla- SE/TS, HVPNL, Rohtak.
9. Sh. H.P. Sharma- SE/Comml., UHBVN, Panchkula.
10. Sh. T.K. Sharma - SE/PD, UHBVN, Panchkula.

The technical feasibility for approval of electrification plan of M/s Model Economic Township Ltd for a load of 88.07 MVA to be released from 220 KV GIS S/Stn. constructed by M/s METL under Self Execution Scheme to be fed from 220 KV Badana and 400 KV S/Stn. Farukhnagar through 220 KV double circuit line as a deposit work. The firm will also deposit the cost of 2 nos. 220 KV bays to terminate 220 KV D/C line at both the feeding end S/Stns. along with requisite charges as per instructions. The site of 220 KV S/Stn shall be located at the road centre on left side of Jhajjar, Gurugram Road.

Director (T-I) Director (T-II) CE (OP) CE/Comml. CE/Plg
UHBVN, Pkl. UHBVN, Pkl. UHBVN RTK UHBVN, Pkl. HVPNL, Pkl

CE/OP&C UHBVN, Pkl CE/TS HVPNL, Pkl SE/TS HVPNL, RTK SE/PD UHBVN, Pkl

SE/Comml.
UHBVN, Pkl

29/03/2017
25/17
under the Division of
necessary action

For Model Economic Township Limited

Authorized Signatory