


All fixtures provided in toilets are as per NBC. Basement will be mechanically ventilated. All spaces (parking basement, services basement etc.) will be naturally ventilated. Standby generating capacity will be provided for the electrical requirement of the total scheme. This therefore includes standby generation for all common services, fire services, lifts etc. And also the entire electrical load for the ventilation. Fire safety measures as per NBC includes smoke detector, heat detector, sprinkler spacing in compliance with code. All external walls are 100mm and all internal walls are 100mm thick. (Valid for all drawings)



Proposed Building Plans For Phase-5, 5A to develop a
 Mix-Land Use colony (98% Residential component & 2%
 Commercial component) under TOD policy over an area
 measuring 11.68875 acres (license no.90 of 2024
 dated:18.07.2024) in the Revenue estate of village
 Hazlipur Jharsa & Bhadshapur, Sector-69, Gurugram
 being developed by Riverday Infrastructure Pvt. Ltd.

morphogenesis.
41, Industrial Estate, Okhla Phase - III
New Delhi - 110020
Tel: 91 11 41828070
Email: studio@morphogenesis.org

R|S|N|S
ARCHITECTS

59, Nora Niwas Bhawani Kunj
(Behind D2), Vasant Kunj,
New Delhi-110070.
Tel.: 011-26898616, 26898617
www.rsms-arch.com

Checked and found ok for Public Health
(Internal) Service only subject to comments in
forwarding letter No. 4063.....DU.3/01/25




BASEMENT 1-02

1-09012025

