

DAKSHIN HARYANA BIJLI VITRAN NIGAM

Memo No. CH-5182-1886

Dated 7-12-2011

From

S.E. (OP) Circle
DHBVN, Faridabad.

To

Xen (OP) Division
DHBVN, old FIBad

Sub:-

Sanction of Load of 2622 kw. with c/d 2000 kVA to M/S Vatik I.T. Park Pvt. Ltd. P.No 1213 Sarai Khawaja, NH-2, Faridabad

Reference your office Memo No. Ch-

dt.

Sanction is hereby accorded for sanction of load of 2622 kw with c/d 2000 kVA to M/S Vatik I.T. Park Pvt. Ltd. P.No 1213 Sarai Khawaja NH-2 FIBad on 1100 volts pressure supply and on 11kV HT ^{NDS} tariff as applicable from time to time with the following conditions,

1. The MMC agreement should be executed by the applicant.
2. Apart from other provisions of instruction of Sales Manual specifically No.21, 102, 105 and 258 applicable in this case & would be taken care of in the first instance.
3. All other formalities as required as per instructions issued/adopted by Nigam time to time shall be completed.
4. Metering equipments including CTs of matching capacity as per specifications and design of Nigam shall be provided.
5. Meter room indicated on the sketch shall be provided at the main entrance gate of the premises as per instruction issued vide sales circular No. D-11/2005 dated 13.07.05.
6. No. applicant senior to the instant applicant/ consumer is waiting sanction of load/extension of load.
7. Full advance consumption deposit will be taken before release of connection.
8. The consumer will deposit the fixed service charges & application processing charges as per sales circular No. D-8/2001 & D-33/2005 respectively.
9. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card Driving license etc., shall be obtained from the applicant/consumer.
10. The consumer will be required to submit documentary proof in support of ownership of land.
11. Non-Judicial stamp worth Rs.3/- on the left hand corner of A&A. The same shall be, got affixed by the SDO before taking further action.
12. The consumer will submit no objection certificate from Water and Pollution Control Board, Haryana.

For VATIK LIMITED

Authorised Signatory

13. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.
14. The Sanctioned load is, required to be built-up, within six months from the release of this connection in terms of SMI No.1.21 and consumer should give undertaking to this effect. If the consumer does not avail the full revised sanctioned load within above period of six months then the revised A&A forms for the availed load verified and accepted on the basis of test report may be sent to this office/competent authorities for acceptance/sanction.
15. All instruction & sales circular of SMI issued as well as amended from time to time by the Nigam will be applicable to the applicant/consumer.
16. Since HT broacher contains old instruction an additional affidavit shall be obtained from the consumer to abide by the provision of the Electricity Act, 2003 and instruction issued by the Nigam there upon from time to time.
17. The applicant shall make compliance of instruction issued by Chief Engineer/Plg. And comml. HVPN, Panchkula issued by Memo No. R-295/Ch-48406 K-194 dt. 8/2005 & instruct. No.16/2007 issued by GM/Comml. Hisar vide memo No.Ch-17/SE/Comml. /R-17/232/05 dt. 21.03.07 before release of connection.
- ~~18. The compliance of instruction issued from time to time which are not incorporate in the above are required to be complied with before release.~~
19. The tariff shall be charged from the individual consumers if any in accordance with HERC regulations and sale instructions/circular issued by the Nigam from time to time. (Only for bulk - Domestic supply)
20. Erection of 11 KV feeder at the cost of consumer with AB Cable.
21. NOC may be obtained from HVPN before release of said load from 66 KV Sub-station if required.
22. The compliance of sales instruction 16/2007 read in conjunction with sales instruction No.30/2006.
23. Load should be released after Aug of the power off from 6.3 MVA to 10 MVA at 33 KV. 50% IAC. FIBED & after prov. independent feeder at his consumer cost.

The A&A from along with others concerned papers as received from DGM (OP) are returned herewith duly accepted by the under signed in view of sale instruction No.48/2006 and instruction issued by C.G.M/P&D DHBVN Hisar vide his office memo No.Ch-161/DD-169 dt. 11.04.07.

DA/As above.

S.E. (OP) Circle
DHBVN, Faridabad.

CC: -

✓ 1/8 Vatika I.T. Park (P) LTD
Faridabad

P. No 12/3 Saran Ka.
For VATIKA LIMITED
Authorised Signatory