



# DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)  
Office of the gmol

Superintending Engineer 'OP' Circle-I  
Mehrauli Road, Gurugram.



0124-2322427



0124-2306590

e-mail [seop1gurugram@dhbvn.org.in](mailto:seop1gurugram@dhbvn.org.in)



To

✓ M/s Gurugram Land and Finance Pvt. Ltd.  
HN-1600, Sec-28, Faridabad-121008, Haryana  
Email: ggn.glf@gmail.com

Memo No. Ch. 53/ Drg.-PLC

Dated: 17/04/2023

Sub:

Assurance for approval of building plan/demarcation plan from DTCP, Haryana for electrification of the colony and installation of electricity distribution infrastructure as per the peak load requirement i.e. 787 KVA of the upcoming DDJAY Colony in Sector-78, Gurugram. Declared load 787KVA.

Ref:

Your firm letter No. dated 12.04.2023 received in this office on dated 13.04.2023.

It is conveyed that power requirement of your project bearing license No.52 of 2023 dated 14.03.2023 which is valid upto 13.03.2028 shall be considered from the nearest source i.e 220/33 KV S/Stn., Gurugram or any other source at the time of release of your load at 33 KV level or the level applied at the time of release of load. The load requirement of this project would be evaluated as per DHBVN norms. The assurance is subject the following conditions:-

1. Availability of power and infrastructure at the time of actual release of load.
2. Deposition of necessary charges by you as per instructions of the Nigam and compliance of all other instructions of Nigam as per standing instructions of the Nigam/HERC regulation.
3. The necessary external & internal infrastructure as per approved Electrification Plan will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer for getting of approval of building plan from DTCP, Chandigarh, Haryana.
5. The validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to apply for revised assurance letter.

  
Superintending Engineer  
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' Divn. DHBVN Manesar for information.