



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the gmol



0124-2322427

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.

Fax
No.

0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

M/s Brisk Infrastructure & Developers Pvt. Ltd.
B-1,1001, Ground Floor, Vasant Kunj
New Delhi-110070
Email: customerservice@brisk.in

Memo No. Ch. 96 / Drg.-PLC

Dated: 06/09/2022

Sub:

Request for assurance of power supply of 1300KW for the proposed commercial plotted colony (License No. 95 of 2021 dated 12.11.2021) over an area measuring 3.6423 acres at Sector-109, District Gurugram, Haryana. Declared Load=1300KW/1444.44KVA.

Ref:

Your firm letter dated 26.08.2022 & 06.9.2022 on the subject.

Reference your request, the technical feasibility has been checked by Xen 'OP' and based on his recommendation it is conveyed that power requirement of your project bearing license No. 95 of 2021 dated 12.11.2021 which is valid upto 11.11.2026 shall be considered from the nearest 220/33KV S/Stn., Gurugram at the time of release of load. The voltage level of supply will be 33KV irrespective of load as DHBVN has been adopted 33KV level of distribution in Sec-58 to 115 & Sec-37C and Sec-37D of Gurugram. The load requirement of this project would be evaluated as per DHBVN norms, However, this assurance is subject to the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary 33/0.433KV external & internal infrastructure will be laid by you at your own cost as per sanctioned load /EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer to get environment clearance from Pollution Control Board of Haryana.
5. As per Nigam's instruction the validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applied for revised assurance letter.


Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' City Divn. DHBVN Gurugram for information.