

From Deputy Director 1
Panchkula

To **M/s SHIVNANDAN BUILDTECH PVT LTD**
4 BATTERY LANE RAJPUR ROAD CIVIL LINES DELHI 110054

Memo No. FS/2018/4 dated : 16/07/2018

Subject : Approval of fire fighting scheme from the fire safety point of view of the with the following details:

Type Of Ownership: Company

Ownership Detail: SHIVNANDAN BUILDTECH PVT LTD

VILLAGE DHANKOT, SECTOR 99 DWARKA EXPRESSWAY, GRUGRAM

Ward No:	0
Town: Gurugram Tehsil: GURGAON District: GURUGRAM	

Reference your letter no. 050261823000876 dated: 13/06/2018 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Gurgaon Sector-29, . The Fire fighting scheme is found as per the N.B.C. 1983 Part IV revised 2005/ guidelines. So that your proposed fire fighting scheme is hereby approved from the fire safety point of view with the following conditions:-

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.

Deputy Director 1

Panchkula

Endst. No: FS/2018/4 Dated: 16/07/2018

A copy if forwarded in reference of Memo No- FS/2018/4 dated 16/07/2018 to the Fire Station Officer, Gurgaon Sector-29, for information and necessary action please.



Deputy Director 1

Panchkula