

**Office of the
Chief Electrical Inspector to Govt., Haryana
SCO 117-118, Sector-17-B, Chandigarh (e-mail: cei_goh@yahoo.com).
Telephone No. 0172-2704090 Fax No. 0172-2710171**

To

M/s Monika Infrastructure Pvt. Ltd.
At Commercial Complex
Sector-53, Gurugram.

Memo No: 6081

Dated: 20/4/2018


Subject: Approval of drawing of M/s Monika Infrastructure Pvt. Ltd. At Commercial Complex, Sector-53, Gurugram.

Reference your letter no. Nil dated 12.04.2018 on the subject noted above.

The single line diagram for installation comprising of 1x3000 KVA, 1x2000 KVA 11/0.433KV T/Fs & 1x2000 KVA, 2x1500 KVA, 1x750 KVA, 2x400 KVA D.G Sets of the subject cited applicant is hereby approved subject to the following:-

1. Relevant provisions of "Central Electricity Authority (Measure relating to Safety and Electric Supply) Regulations, 2010" will be complied with.
2. The generation/transmission/distribution/trading/consumption/captive use of electricity will be made after necessary approval of competent Authority prescribed in the Electricity Act 2003 and the Electricity Rules 2005. A copy of relevant approval be furnished white offering inspection of the installation.
3. Various electrical equivalents will be placed / installed as per National building code and others prevalent practice.
4. All LV /MV panels will be placed inside enclosure at a safe place.
5. The energy meters will be installed at the main gate of the premises.
6. Neutral point and body of transformers be provided two separate and distinct earths with copper/GI strip as per IS :3043-1987.
7. The 11 KV VCB will have breaking capacity of 18.4KA.
8. The distance between building and sub station should be maintained as per norms.

DA/Approved Drawing


**Chief Electrical Inspector,
to Govt., Haryana, Chandigarh
(Camp at Gurgaon)**

CC: The Executive Engineer, Electrical Inspectorate, Haryana, Gurugram for information.