

# DAKSHIN HARYANA BIJLI VITRAN NIGAM

DHBN

Superintending Engineer 'OP' Circle  
Mehrauli Road, Gurgaon.



0124-2322427

0124-2306590

e-mail [se.gurgaon@gmail.com](mailto:se.gurgaon@gmail.com)

To:

M/s S.V. Housing Pvt. Ltd.  
304, Kanchan House,  
Karampura Commercial Complex,  
New Delhi-110015

Memo No. Ch. - 102 / Drg.-PLC

Dated: 5/12/2014

Sub:

Assurance of supply of power load for ultimate power load for setting up of  
commercial colony over an area measuring 4.20 acres, village- Sihi, Sector-  
83, Gurgaon.

Reference your letter dated 27<sup>th</sup> .11.2014 on the above subject.

It is hereby assured that the power requirement of tentative load of 7.667MVA  
shall be considered from the nearest sub-station at the time of actual requirement as per  
DHBN norms. However, the voltage level of the supply will be 33KV from Sector-58 to  
Sector-115, Gurgaon.

Superintending Engineer  
'OP' Circle DHBN, Gurgaon

C.C.to: -

The XEN 'OP' Divn. DHBN, Manesar.