



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the

Superintending Engineer 'OP' Circle,
Mehrauli Road, Gurgaon.

0124-2322427

Fax No. 0124-2306590

e-mail: se.gurgaon@gmail.com

To

✓ M/s Clarion Properties
Limited. Plot.No.-8,
Sector-44, Gurgaon-122002

Memo No.Ch-66 /Drg-PLC

Dated: 23.10.2015

Sub:

Ultimate power load requirement setting up a Commercial Colony on a land measuring 5.846875 acres (Licence No.93 of 2012 dated-05.09.2012.Licence No.30&31 of 2014 dated-12.06.2014) situated in Revenue Estate of village-Dhankot, Sector-102, Gurgaon memo no979/SD/BS/2015/9451 dated-05.06.2015.

Reference your letter dated-23.10.2015 on the aabove subject.

It is hereby assured that power requirement of tentative load of 5234 KW shall be considered from the nearest S/Stn. at the time of actual requirement as per DHBVN, norms. However the voltage level of the supply will be 33 KV from sector-58 to sector-115, Gurgaon.


Superintending Engineer
'OP' Circle DHBVN, Gurgaon.

CC to:-

The Xen 'OP' City Divn. DHBVN, Gurgaon.

