DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the ginol

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.

0124-2322427

Fax No. 0124-2306590

e-mail seop1gurugram@dhbvn.org.in

To

M/s Experion Developers Pvt. Ltd.
F-9, First Floor, Manish Plaza-1
Plot No.7, MLU Sector-10 Dwarka
New Delhi-110075.

Memo No. Ch. 12 / Drg.-PLC Dated: 30 /05/2025

Sub: **Assurance Certificate for setting up of Mix Land use (95.58% Group Housing & 4.41& Commercial) under TOD Policy over an area measuring 7.81875 acers in the revenue estate of village-Harsaru Sector-88A, District-Gurugram to be develop by M/s Experion Developers Pvt. Ltd. Declared total 8.067 MVA load.**

Ref : Your Firm Letter No.Nil dated 28.05.2025.

It is hereby assured that the power requirement of tentative load of 8.067 MVA shall be considered from the nearest 220/33KV substation at the time of actual requirement as per DHBVN norms at voltage level of 33KV subject to the following conditions:-

1. Subject to availability of power and infrastructure at the time of actual release of load.
2. Necessary charges will be got deposit by your firm as per latest instructions of the Nigam and compliance of all other instructions of Nigam as per standing instructions of the Nigam/HERC regulation.
3. The necessary infrastructure will be laid by you at your own cost. The piece of land will be provide by you for the switching station / sub-stalion as per instructions of the Nigam.
4. The letter will be valid till the validity of license in view of Sales Circular No.D-6/2022 issued by CE/Commercial DHBVN, Hisar vide Memo No. Ch-06/SE/C/R-16 /380/Vol-l dated 10.03.2022

Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-
The Xen 'OP' City Divn. DHBVN, Gurugram for information.