



UTTAR HARYANA BIJLI VITRAN NIGAM LIMITED

(A Government of Haryana Undertaking)
Registered Office, C-16, Vidyut Sadan, Sector-6, Panchkula, Haryana
Office of Deputy Secretary Technical, UHBVN, Panchkula
Ph. No. 0172-3019120 E-mail- dst@uhbvn.org.in

To

The Chief Engineer/OP
UHBVN, Rohtak.

Memo No. Ch- 3/DST/Elect Plan/Case File No. 46/JJR-19-20
Dated:- 18.12.2019

Subject:- Approval of Electrification plan of Group Housing Colony being developed by M/s HL Promoters B-44, Vishrantika Apartment, Plot No. 5A, Sector-3, Dwarka, New Delhi on 21.709 Acre land in Sector-37, Bahadurgarh for a load of 4530.16 kW (5034 kVA) on 33 kV supply pressure proposed to be fed from 220 kV S/Stn. Nuna Majra.

This is with reference to your office memo No. Ch-2/C-549/DRG-JJR dated 09.09.2019 vide which Electrification plan of Group Housing Colony being developed by M/s HL Promoters on 21.709 Acre land in Sector - 37 Bahadurgarh for a load of 4530.16kW / 5034 kVA was forwarded for processing the case. The renewal of the licenses under which the electrification plan has been submitted was intimated by SE(OP) Circle UHBVN, Jhajjar vide his office memo No. Ch-17/CC-178 dated 30.10.2019 i.e. the License No. 120 of 2014 (5.278 Acre) valid up to 21.08.2024 renewed vide Endst No. LC3101-B-JE(MK)-2019/26250 dated 24.10.2019 and 60 of 2014 (16.43125 Acre) to the developer valid up to 29.08.2024 renewed vide Endst No. LC3101-JE(MK)-2019/26464 dated 25.10.2019

In this context, it is intimated that as recommended by your office the electrification layout plan of Group Housing colony being developed by M/s HL Promoters on 21.709 Acre land in Sector - 37 Bahadurgarh has been considered and approved on single point supply on 33kv level as per Option I of SC No. U-7/2013 on proposed 33kv Independent feeder (M/s Omaxe Sector-14 Bahadurgarh, M/s H.L. Promoters and M/s Garg Inox) to be fed from 220kV S/Stn. Nuna Majra at the cost of the 3 No. applicants subject to


1. Allocation of 33kV bay by HVPNL.
2. Erection of 33kV line (ACSR150 mm²) on 11 mtr. PCC poles from 220 kV S/Stn Nuna Majra at the cost of the consumers (M/s Garg Inox 4.25 MVA, M/s H.L. Promoters 5.93 MVA and M/s Omaxe Sector-14 Bahadurgarh 7.64 MVA)
3. The ROW for erection of 33kV line is available / shall be made available by the consumer
4. Installation of DT's of standard quality as per Nigam Specifications to cater to the total load requirement of township and the maximum loading of the T/Fs will be 80% i.e.; as per BoM (DTs capacity to be installed=4x1600 kVA, 33/0.433).



5. The developer will deposit the requisite bank guarantee before release of connection, if required.
6. The field officer shall ensure that the developer erects / install the equipment as per the approved bill of material.
7. Inspection charges as per HERC norms be got deposited from the developer, if the work executed under Self Execution Scheme.
8. These load norms will be revised / updated every three years in sync with updation of EDC charges and will be made applicable prospectively.
9. The Firm shall bear the inspection fee of the Chief Electrical Inspector to Government of Haryana for inspection of system.
10. The main meter room should be locked and the keys of the meter room should be with some authorized persons and conveniently located near the main gate with free accessibility as per existing instructions of the Nigam.
11. Undertaking well defining the responsibility in the event of breakage of seals on metering distribution panel or the main bus bar enclosures etc. be had in each case.
12. There should be double earthing arrangement of each equipment.
13. The quality of material to be used shall be checked & approved by authorized person of UHBVN as per instructions.
14. The Nigam officer shall personally ensure compliance of all above Technical & commercial points before releasing the connections.
15. UHBVN reserves the right to recover the amount of inadequacy if any, arising later on.
16. The developer will abide by all the rules and regulations as amended from time to time along with fulfillment of all terms and conditions of SC No. U-15/2015, 31/2016, 35/2016, 20/2017 and 7/2019.

This bears the approval of Director/Projects UHBVN, Panchkula.

DA/Files


Dy. Secy. Technical,
UHBVN, Panchkula.

Cc

1. SPS to Director/Projects UHBVN, Panchkula for kind information of Director/Projects, please.
2. SE(OP) Circle UHBVN, Jhajjar for information please.